

# Beach Energy Resources (NZ) Kupe Ltd Kupe Production Station

Monitoring Programme

Annual Report

2022-2023

Technical Report 2023-59



Working with people | caring for Taranaki



Taranaki Regional Council  
Private Bag 713  
Stratford

ISSN: 1178-1467 (Online)  
Document: 3199943 (Word)  
Document: 3200801 (Pdf)  
October 2023

**Beach Energy Resources (NZ) Kupe Ltd**

**Kupe Production Station**

Monitoring Programme

Annual Report

2022-2023

Technical Report 2023-59



**Beach Energy Resources (NZ) Kupe Ltd**  
**Kupe Production Station**  
Monitoring Programme  
Annual Report  
2022-2023

Technical Report 2023-59

Taranaki Regional Council  
Private Bag 713  
Stratford

ISSN: 1178-1467 (Online)  
Document: 3199943 (Word)  
Document: 3200801 (Pdf)  
October 2023



## Executive summary

Beach Energy Resources NZ (Kupe) Ltd (the Company) operates a hydrocarbon production station located on Inaha Road at Manaia, in the Inaha and Kapuni catchments. The Kupe Production Station processes oil and gas from the offshore Kupe wells.

This report for the period July 2022 to June 2023 describes the monitoring programme implemented by the Taranaki Regional Council (the Council) to assess the Company's environmental and consent compliance performance during the period under review. The report also details the results of the monitoring undertaken and assesses the environmental effects of the Company's activities.

**During the monitoring period, Beach Energy Resources NZ (Kupe) Ltd demonstrated a high level of environmental performance and high level of administrative performance.**

The Company holds 12 resource consents in relation to the Kupe facilities, which include a total of 134 conditions setting out the requirements that the Company must satisfy. The Company holds one consent to allow it to take and use groundwater, one consent to discharge stormwater into the Kapuni Stream, one consent to install groundwater bores, two consents to discharge emissions into the air from the production station, four coastal consents relating to the offshore facilities, and five consents which covered activities during the development phase of the Kupe project.

The Council's monitoring programme for the year under review included four inspections, four samples collected for physicochemical analysis, two biomonitoring surveys of receiving waters, and an ambient air quality analyses. The consent holder provided data on flaring, water abstraction and stormwater discharges.

Site inspections found that the stormwater systems were constructed and maintained in accordance with consent conditions and were operating effectively. Some minor housekeeping issues were noted during the inspections, but they were rapidly cleaned up and presented no potential to cause adverse effect to the environment.

Biomonitoring of the receiving waters did not indicate that the stormwater discharges from the Kupe Production Station had caused adverse effects on the water quality of the Kapuni Stream.

There were no adverse effects on the environment resulting from the exercise of the air discharge consents. The ambient air quality monitoring at the site showed that levels of nitrogen oxides were below levels of concern at the time of sampling. No offensive or objectionable odours were detected beyond the boundary during inspections and there were no complaints in relation to air emissions from the site.

For reference, in the 2022-2023 year, consent holders were found to achieve a high level of environmental performance and compliance for 878 (87%) of a total of 1007 consents monitored through the Taranaki tailored monitoring programmes, while for another 96 (10%) of the consents a good level of environmental performance and compliance was achieved. A further 27 (3%) of consents monitored required improvement in their performance, while the remaining one (<1%) achieved a rating of poor.

In terms of overall environmental and compliance performance by the consent holder over the last several years, this report shows that the consent holder's performance remains at a high level.

This report includes recommendations for the 2023-2024 year.

## Table of contents

	Page	
1	Introduction	1
1.1	Compliance monitoring programme reports and the Resource Management Act 1991	1
1.1.1	Introduction	1
1.1.2	Structure of this report	1
1.1.3	The Resource Management Act 1991 and monitoring	1
1.1.4	Evaluation of environmental performance	2
1.2	Process description	2
1.3	Resource consents	4
1.3.1	Kupe Production Station	5
1.3.2	Related consents	6
1.4	Monitoring programme	6
1.4.1	Introduction	6
1.4.2	Programme liaison and management	6
1.4.3	Site inspections	7
1.4.4	Chemical sampling	7
1.4.5	Biomonitoring surveys	7
2	Results	8
2.1	Water	8
2.1.1	Inspections	8
2.1.2	Results of discharge monitoring	9
2.1.3	Results of receiving environment monitoring	10
2.1.3.1	Chemical	10
2.1.3.2	Biomonitoring	11
2.1.4	Summary of water abstractions reported by Beach Energy	13
2.2	Air	14
2.2.1	Inspections	14
2.2.2	Results of receiving environment monitoring	14
2.2.2.1	Carbon monoxide and combustible gases	14
2.2.2.2	PM <sub>10</sub> particulates	15
2.2.2.3	Nitrogen oxides	15
2.2.3	Summary of flaring volumes reported by Beach Energy	15
2.3	Incidents, investigations, and interventions	16



3	Discussion	17
3.1	Discussion of site performance	17
3.2	Environmental effects of exercise of consents	17
3.3	Evaluation of performance	17
3.4	Recommendations from the 2021-2022 Annual Report	27
3.5	Alterations to monitoring programmes for 2023-2024	27
4	Recommendations	28
	Glossary of common terms and abbreviations	29
	Bibliography and references	31
	Appendix I Resource consents held by Beach Energy Resources (Kupe) Ltd	
	Appendix II Categories used to evaluate environmental and administrative performance	

## List of tables

Table 1	Summary of resource consents held by Beach Energy for the Kupe Production Station	5
Table 2	Consents related to the development phase of the Kupe facilities	6
Table 3	Monitoring results for STW002086 and STW002096	9
Table 4	Receiving environment results for the Kapuni Stream	10
Table 5	Location of biomonitors sites in the Kapuni Stream	11
Table 6	Summary of performance for consent 6531-1	17
Table 7	Summary of performance for consent 6532-1	18
Table 8	Summary of performance for consent 6533-1	19
Table 9	Summary of performance for consent 6543-1	20
Table 10	Summary of performance for consent 6545-1	20
Table 11	Summary of performance for consent 6546-1	22
Table 12	Summary of performance for consent 6629-1	23
Table 13	Summary of performance for consent 6979-1	24
Table 14	Summary of performance for consent 7010-1	25
Table 15	Evaluation of environmental performance over time	26

## List of figures

Figure 1	Location of Kupe Gas Project	3
Figure 2	Components of the Kupe Gas Project	4
Figure 3	Kupe Production Station sampling and biomonitors sites	9

Figure 4	Stormwater discharge volumes for Kupe Production Station	10
Figure 5	Biomonitoring sites in the Kapuni Stream in relation to the Kupe Production Station, with taxa number, MCI scores and SQMCI scores for each site, spring 2022	12
Figure 6	Biomonitoring sites in the Kapuni Stream in relation to the Kupe Production Station, with taxa number, MCI scores and SQMCI scores for each site, summer 2023	13
Figure 7	Daily water abstraction volumes for Kupe Production Station under consent 7010-1	14
Figure 8	Monthly gas flaring and fuel use for Kupe Production Station	16

## List of photos

Photo 1	Kupe Production Station	3
---------	-------------------------	---

# 1 Introduction

## 1.1 Compliance monitoring programme reports and the Resource Management Act 1991

### 1.1.1 Introduction

This report is for the period July 2022 to June 2023 by the Taranaki Regional Council (the Council) on the monitoring programme associated with resource consents held by Beach Energy Resources NZ (Kupe) Ltd (the Company). The Company operates a hydrocarbon production station situated on Inaha Road at Manaia, in the Inaha and Kapuni catchments.

The report includes the results and findings of the monitoring programme implemented by the Council in respect of the consents held by the Company that relate to abstractions and discharges of water within the Inaha and Kapuni catchments, and the air discharge permit held by the Company to cover emissions to air from the site. This report is the 14<sup>th</sup> annual report to be prepared by the Council to cover the Company's air, land and water discharges and their effects.

### 1.1.2 Structure of this report

**Section 1** of this report is a background section. It sets out general information about:

- consent compliance monitoring under the *Resource Management Act 1991* (RMA) and the Council's obligations;
- the Council's approach to monitoring sites through annual programmes;
- the resource consents held by the Company in the Inaha and Kapuni catchments;
- the nature of the monitoring programme in place for the period under review; and
- a description of the activities and operations conducted at the Kupe Production Station.

**Section 2** presents the results of monitoring during the period under review, including scientific and technical data.

**Section 3** discusses the results, their interpretations, and their significance for the environment.

**Section 4** presents recommendations to be implemented in the 2023-2024 monitoring year.

A glossary of common abbreviations and scientific terms, and a bibliography, are presented at the end of the report.

### 1.1.3 The Resource Management Act 1991 and monitoring

The RMA primarily addresses environmental 'effects' which are defined as positive or adverse, temporary or permanent, past, present or future, or cumulative. Effects may arise in relation to:

- a. the neighbourhood or the wider community around an activity, and may include cultural and social-economic effects;
- b. physical effects on the locality, including landscape, amenity and visual effects;
- c. ecosystems, including effects on plants, animals, or habitats, whether aquatic or terrestrial;
- d. natural and physical resources having special significance (for example recreational, cultural, or aesthetic); and
- e. risks to the neighbourhood or environment.

In drafting and reviewing conditions on discharge permits, and in implementing monitoring programmes, the Council is recognising the comprehensive meaning of 'effects' in as much as is appropriate for each activity. Monitoring programmes are not only based on existing permit conditions, but also on the obligations of the RMA to assess the effects of the exercise of consents. In accordance with Section 35 of the RMA, the Council undertakes compliance monitoring for consents and rules in regional plans, and maintains an overview of the performance of resource users and consent holders. Compliance monitoring, including both activity and impact monitoring, enables the Council to continually re-evaluate its approach and that of consent holders to resource management and, ultimately, through the refinement of methods and considered responsible resource utilisation, to move closer to achieving sustainable development of the region's resources.

### 1.1.4 Evaluation of environmental performance

Besides discussing the various details of the performance and extent of compliance by the consent holders, this report also assigns a rating as to each Company's environmental and administrative performance during the period under review. The rating categories are high, good, improvement required and poor for both environmental and administrative performance. The interpretations for these ratings are found in Appendix II.

For reference, in the 2022-2023 year, consent holders were found to achieve a high level of environmental performance and compliance for 878 (87%) of a total of 1007 consents monitored through the Taranaki tailored monitoring programmes, while for another 96 (10%) of the consents a good level of environmental performance and compliance was achieved. A further 27 (3%) of consents monitored required improvement in their performance, while the remaining one (<1%) achieved a rating of poor. <sup>1</sup>

## 1.2 Process description

Development of the Kupe Production Station (Photo 1), offshore pipelines and offshore platform began in mid-2006. Natural gas and light oil are extracted from the Kupe Field which is located offshore, approximately 30 km south of Ohawe Beach on the South Taranaki coast. Raw gas and light oil extracted from the field offshore are transported to shore via pipeline and processed at an onshore production station. The location of the Kupe Field and the production station is shown in Figure 1.

The offshore platform is situated in approximately 35 m deep water and comprises a topside deck supported by four legs fixed to the seabed. Installation of the offshore platform commenced in early 2007. The offshore platform and production wells are outside of the 12 nautical mile coastal marine area (CMA) boundary and therefore outside the jurisdiction of this Council.

The single subsea pipeline enables delivery of the raw natural gas and light oil to the onshore production station. Parallel to the subsea pipeline, utility lines transfer chemicals, power and fibre optic links from the shore to the offshore platform (Figure 2). Horizontal directional drilling (HDD) was used to install the pipelines under the 40 m high sea cliffs at the end of Inaha Road in order to link the offshore and onshore components and to avoid disturbance of the foreshore and shoreline seabed. The HDD entry point is 500 m inland of the coastline and the exit point emerges 1,800 m offshore.

---

<sup>1</sup> The Council has used these compliance grading criteria for more than 19 years. They align closely with the 4 compliance grades in the MfE Best Practice Guidelines for Compliance, Monitoring and Enforcement, 2018



Photo 1 Kupe Production Station




Figure 1 Location of Kupe Gas Project

Note: Figure 1 sourced from: <http://www.beachenergy.com.au/new-zealand/>

The production station is located at the southern end of Inaha Road, occupying roughly 19 ha of land. It includes storage and truck loading facilities for LPG and condensate export. The KPS flare systems consists of a high pressure elevated emergency flare and a low pressure ground level operational flare system. The

emergency and operational flare systems provide a means of safely disposing hydrocarbon gases which are released either by:

- Process operations during start-up or shutdown;
- Pressure relief during plant upset or emergency conditions;
- Emergency depressuring;
- Maintenance operations.

A series of ponds provide a natural cleaning system for stormwater before discharging from the site. Commissioning of the production station began in early 2009, with commercial production commencing in November 2009.

Onshore pipelines have been installed to enable the transfer of raw gas from the HDD shore crossing to the production station, and to transfer the sales gas from the production station to the Kapuni Gas Treatment Plant.




Figure 2 Components of the Kupe Gas Project

Note: Figure 2 sourced from: <http://www.originenergy.com.au/1222/Kupe-Gas-Project>

### 1.3 Resource consents

The Company holds 12 resource consents the details of which are summarised in the table below. Summaries of the conditions attached to each permit are set out in Section 3 of this report.

A summary of the various consent types issued by the Council is included in Appendix I, as are copies of all permits held by the Company during the period under review.

### 1.3.1 Kupe Production Station

Table 1 Summary of resource consents held by Beach Energy for the Kupe Production Station

Consent number	Purpose	Granted	Review	Expires
<i>Water abstraction permit</i>				
7010-1	To take and use up to 3,500 m <sup>3</sup> /day groundwater at a maximum rate of 40 L/s as a combined total from up to seven water bores in a bore field for the purpose of horizontal directional drilling, pipeline hydro-testing, production station operation at the Kupe production station and operations at the Manutahi-D, Manutahi-C, and Kauri-F wellsites	November 2006	June 2029	June 2039
<i>Water discharge permit</i>				
6543-1	To discharge pipeline hydrotesting water and treated stormwater from the Kupe Production Station via a stormwater/firewater storage pond system, and to discharge stormwater from the 'Dangerous Goods Storage' stormwater system into the Kapuni Stream	June 2005	June 2029	June 2039
<i>Air discharge permits</i>				
6545-1	To discharge emissions to air from combustion involving the flaring of petroleum products incidental to the treatment of gas at the Kupe Production Station	June 2005	June 2029	June 2039
6546-1	To discharge emissions to air as products of combustion from the Kupe Production Station involving equipment burning natural gas as fuel where the maximum heat release is in excess of 10 megawatts, together with miscellaneous emissions	June 2005	June 2029	June 2039
<i>Land use permit</i>				
6979-1	To install, construct and maintain up to seven water bores for horizontal directional drilling, pipeline hydro-testing, and production station operation purposes	November 2006	June 2029	June 2039
<i>Coastal permits</i>				
6531-1	To disturb the seabed and foreshore of the coastal marine area by the process of erection, placement, use, alteration, extension, maintenance or removal of up to six pipelines and one power/fibre optic cable connecting an offshore wellhead/platform to the foreshore at mean high water spring	December 2005	June 2029	June 2039
6532-1	To erect, place, use, reconstruct, alter, extend and maintain within the coastal marine area up to six pipelines connecting an offshore wellhead/platform to the foreshore at mean high water spring, with structures situated under the seabed from approximately 1,200 m offshore to mean high water spring, and the related occupation of the seabed	December 2005	June 2029	June 2039
6533-1	To occupy the coastal marine area for a distance of 250 m either side of the centre-line of a 100 m wide pipeline corridor, from the outer limit of the territorial sea of New Zealand to mean high water spring, in a manner that will restrict public access	December 2005	June 2029	June 2039



Consent number	Purpose	Granted	Review	Expires
6629-1	To erect, place, use, reconstruct, alter, extend and maintain within the coastal marine area one power/fibre optic cable connecting an offshore wellhead/platform to the foreshore at mean high water spring, with structures situated under the seabed from approximately 1200 m offshore to mean high water spring, and the related occupation of the seabed	October 2005	June 2029	June 2039

### 1.3.2 Related consents

The Company also holds a number of consents relating to the development phase of the Kupe facilities which did not require active monitoring during the period under review. A summary of these consents is provided in Table 2. Copies of these consents are available from the Council upon request.

Table 2 Consents related to the development phase of the Kupe facilities

Consent number	Purpose	Granted	Review	Expiry
6534-1	To discharge up to 1000 m <sup>3</sup> of contaminants (up to 600 m <sup>3</sup> of drilling muds, drilling cuttings and aquifer water and up to 400 m <sup>3</sup> of gauge run water) from two horizontal directional drilling exit points through the seabed approximately 1200 m from mean high water spring within the coastal marine area	October 2005	June 2029	June 2039
6535-1	To divert water from aquifers in the coastal marine area likely to be encountered during activities associated with horizontal directional drilling of two drill lines	October 2005	June 2029	June 2039
6537-2	To discharge treated stormwater from a horizontal directional drilling site onto and into land	March 2023	June 2027	June 2037

## 1.4 Monitoring programme

### 1.4.1 Introduction

Section 35 of the RMA sets obligations upon the Council to gather information, monitor and conduct research on the exercise of resource consents within the Taranaki region. The Council is also required to assess the effects arising from the exercising of these consents and report upon them.

The Council may therefore make and record measurements of physical and chemical parameters, take samples for analysis, carry out surveys and inspections, conduct investigations and seek information from consent holders.

The monitoring programme for the Kupe Production Station site consisted of four primary components.

### 1.4.2 Programme liaison and management

There is generally a significant investment of time and resources by the Council in:

- ongoing liaison with resource consent holders over consent conditions and their interpretation and application;
- discussion over monitoring requirements;
- preparation for any consent reviews, renewals or new consent applications;
- advice on the Council's environmental management strategies and content of regional plans; and



- consultation on associated matters.

### 1.4.3 Site inspections

The Kupe Production Station was visited four times during the monitoring period. With regard to consents for the abstraction of or discharge to water, the main points of interest were plant processes with potential or actual discharges to receiving watercourses, including contaminated stormwater and process wastewaters. Air inspections focused on plant processes with associated actual and potential emission sources and characteristics, including potential odour, dust, noxious or offensive emissions. Sources of data being collected by the Company were identified and accessed, so that performance in respect of operation, internal monitoring, and supervision could be reviewed by the Council. The neighbourhood was surveyed for environmental effects.

### 1.4.4 Chemical sampling

The Council undertook sampling of both the discharges from the site and the water quality upstream and downstream of the discharge point and mixing zone.

The production station discharges were sampled once, and the samples analysed for chlorides, conductivity, hydrocarbons, pH, suspended solids and turbidity. The Kapuni Stream was sampled concurrently, with the samples analysed for the same constituents.

The Council undertook sampling of the ambient air quality outside the boundary of the site. Two nitrogen oxide measuring devices were deployed in the vicinity of the plant on one occasion during the year under review.

### 1.4.5 Biomonitoring surveys

Biological surveys were performed on two occasions in the Kapuni Stream to determine whether or not the discharge of treated stormwater and uncontaminated site and process effluent from the site has had a detrimental effect upon the communities of the stream.

## 2 Results

### 2.1 Water

#### 2.1.1 Inspections

Four inspections were carried out at the Kupe Production Station in the 2022-2023 year. These were on 9 August and 19 October 2022, and 7 March and 29 May 2023.

##### 9 August 2022

Persistent rain and strong winds were present during the inspection. The stormwater system was observed to be working well, with all stormwater being collected and directed for treatment prior to discharge from the site. The site was tidy and processes appeared to be well managed as no spills or stains were evident on the ground. Operationally good practices were being adhered to, with drip trays and chemical bunding in use. Hydrocarbon in the form of diesel was noted within the fire water/stormwater pond and staff advised that a faulty valve had been identified as the cause of the spill. The diesel was starting to emulsify and works to clean up the spill were scheduled to be undertaken once the weather settled. Visually the stream looked the same downstream as it did upstream of the discharge point. A pilot flare was in operation at the time of inspection. The flame was clean burning with no smoke or odour noted on or off site.

##### 19 October 2022

Good bunding practices were observed with discharge valves shut. Drums were stored in the correct locations. No stains or recent spills were evident and the site appeared to be tidy and well maintained. The hydrocarbon spill from the water pump noted during the previous inspection had been cleaned up and removed, and no hydrocarbon sheen was noted in the pond. There was no discharge from the site at the time of inspection and no effects were noted below the discharge point in the river. A pilot flare was in operation with a clean burning flame. No odour or smoke was detected.

##### 7 March 2023

The site was generally tidy, however it was noted that the area around the workshop and roadside drains could benefit from a clean and tidy. An oil spill had occurred the previous day from a truck collecting sewerage. Steps had been taken to absorb the oil but it had not yet been removed at the time of the inspection. A vehicle had driven through the oil causing staining to spread up one of the roadways and staff were advised to take action to prevent another vehicle from driving over the spill. It was also noted that carbon was being stored in sacks near the workshop. Some of these sacks appeared to be leaching, with oil noted on the ground between the sacks. The metallised area adjacent to the sacks appeared to be stained with oil also. Staff were advised that these sacks needed to be bunded or removed from site and the area cleaned up. A pilot flare was visible during the inspection. No smoke was detected above the flare at the time of inspection. Staff advised that processes at the site had changed, and that start up could now be completed without the need to flare, thus reducing the volume of gas flared.

##### 29 May 2023

In general the site was tidy. It was raining and extremely windy at the time of inspection and some debris, such as feathers and organic matter, had collected in the ring drains and around the external roadways. The waste material in sacks behind the workshop noted in the previous inspection had been removed but the spillage from the bags remained on the ground and this needed to be removed. A discussion was had with staff about removing of old garnet from around the blast sheds and bund where the wind monitoring station is located, and the need to remind contractors that remote abrasive blasting should to be undertaken within an enclosed area. No discharge was occurring at the time of the inspection and the stream looked good, with no effects noted. A pilot flare was in operation.

## 2.1.2 Results of discharge monitoring



Figure 3 Kupe Production Station sampling and biomonitoring sites

Water quality sampling of the discharge to the Kapuni Stream was undertaken once during the 2022-2023 period. Table 3 presents the results of this sampling. Monitoring sites in relation to Kupe Production Station are shown in Figure 3. To differentiate any effects on the water quality of the discharge resulting from combination with the Siggs Road stormwater, which shares the same outlet at STW002086, a sample is also taken on site at the outlet of the production station ponds system (STW002096).

Table 3 Monitoring results for STW002086 and STW002096

Parameter	Units	5 May 2023		Consent 6543-1 limits
		STW002086	STW002096	
Chloride	g/m <sup>3</sup>	15	16	230
Conductivity	g/m <sup>3</sup>	14.4	14.8	-
Hydrocarbons	g/m <sup>3</sup>	<0.7	<0.7	15
pH	g/m <sup>3</sup>	7.2	7.2	6.0 - 9.0
Suspended solids	g/m <sup>3</sup>	15	8	100
Turbidity	NTU	7.5	4.5	-

The results are indicative of an uncontaminated discharge, with chloride, hydrocarbons, pH and suspended solids all complying with consent conditions.

The Company records the volume of each discharge which is pumped from the site to the outlet structure adjacent to the Kapuni Stream. A summary of the total volume of stormwater discharged each month is provided in Figure 4.




Figure 4 Stormwater discharge volumes for Kupe Production Station

## 2.1.3 Results of receiving environment monitoring

### 2.1.3.1 Chemical

Table 4 Receiving environment results for the Kapuni Stream

Parameter	Units	5 May 2023		Consent 6543-1 conditions
		Upstream KPN000488	Downstream KPN000492	
Chloride	g/m <sup>3</sup>	10	10	-
Conductivity	g/m <sup>3</sup>	9.4	9.7	-
Hydrocarbons	g/m <sup>3</sup>	<0.7	<0.7	No conspicuous oil, films or foams
pH	g/m <sup>3</sup>	7.3	7.4	-
Suspended solids	g/m <sup>3</sup>	70	121	No conspicuous change
Temperature	°C	14.7	14.8	No conspicuous change
Turbidity	NTU	19	24	-

Water quality sampling of the Kapuni Stream was undertaken in conjunction with stormwater discharge sampling. The results are presented in Table 4. The sampling sites are shown in Figure 3 and include upstream and downstream points.

The results showed little or no change for most parameters between upstream and downstream sites. The already very high suspended solids and turbidity did increase downstream but as there was a low sediment load in the discharge this was more likely due to flooding in the stream. There was no conspicuous change in the colour or clarity of the stream between the upstream and downstream sites.

### 2.1.3.2 Biomonitoring

The Council's 'kick-sampling' technique was used at three sites on 25 October 2022 and 15 March 2023 to collect streambed macroinvertebrates from the Kapuni Stream in relation to the stormwater discharge from the Kupe Production Station (Table 5, Figure 3). The surveys provided data to assess any potential impacts the discharge has had on the macroinvertebrate communities of the stream. Samples were processed to provide number of taxa (richness), Macroinvertebrate Community Index (MCI), and Semi-quantitative Macroinvertebrate Community Index (SQMCI) scores for each site.

Table 5 Location of biomonitoring sites in the Kapuni Stream

Site No.	Site code	Location
1	KPN000488	Upstream of Production Station stormwater discharge
2	KPN000490	50 m downstream of Production Station stormwater discharge
3	KPN000492	200 m downstream of Production Station stormwater discharge

Taxa richness is the most robust metric when ascertaining whether a macroinvertebrate community has been exposed to toxic discharges. When exposed to toxic discharges, macroinvertebrates may die and be swept downstream or deliberately drift downstream as an avoidance mechanism (catastrophic drift). The MCI is a measure of the overall sensitivity of the macroinvertebrate community to the effects of organic pollution in stony streams. It is based on the presence/absence of taxa with differing sensitivity to organic pollution. The SQMCI is similar to the MCI, but accounts for relative abundances of the taxa found as well as sensitivity to pollution. Significant differences in taxa richness, MCI or SQMCI between sites may indicate the degree of adverse effects (if any) of the discharges being monitored.

#### Spring survey, October 2022

Taxa richness was moderately low, ranging from 10-12 taxa (Figure 5). Site 1 recorded the lowest number of taxa to date, with 10 taxa present. MCI scores characterised all sites as having 'good' macroinvertebrate community health. There were no significant differences in MCI scores recorded between the three sites surveyed, and all MCI scores were above the previously recorded range, and above their respective median scores. Two taxa were dominant at all three sites including; one 'highly sensitive' taxon (mayfly (*Deleatidium*)) and one 'tolerant' taxon (chironomid midge (*Orthocladinae*)). MCI scores were higher than those recorded by the previous survey at all three sites, with significant increases recorded at both site 2 and site 3.

SQMCI scores were reflective of 'very good' macroinvertebrate health at all sites. SQMCI scores were higher than those recorded by the previous survey at all three sites, with site 2 recording a significantly higher score. All SQMCI scores were within the range of those recorded previously.

Overall, these macroinvertebrate metrics suggest that the stormwater discharges from the Kupe Production Station have not caused significant adverse effects on the macroinvertebrate communities of the Kapuni Stream.





Figure 5 Biomonitoring sites in the Kapuni Stream in relation to the Kupe Production Station, with taxa number, MCI scores and SQMCI scores for each site, spring 2022

#### Summer survey, March 2023

Taxa richness was moderately low, ranging from 10-13 taxa (Figure 6). MCI scores were all characterised as having 'fair' macroinvertebrate community health. There were no significant differences in MCI scored recorded between the three sites surveyed. All MCI scores were below the previously recorded range as well as below their respective median scores. MCI scores were lower than those recorded by the previous survey at all three sites, with significant decreases recorded at site 2 and site 3. Two taxa were dominant at all three sites including: one 'highly sensitive' taxon (mayfly (*Deleatidium*)) and one 'moderately sensitive' taxon (beetle (Elmidae)).

SQMCI scores were reflective of 'excellent' macroinvertebrate health at site 1 and 2, and 'very good' macroinvertebrate health at site 3. SQMCI scores for all sites were higher than their respective median, however only site 1 and site 2 scores were higher than the previously recorded score. There was a significant difference between the SQMCI scores at site 1 and site 3, however these are likely caused by slight habitat differences between the sites, such as bank stability and substrate composition.

Overall, the macroinvertebrate metrics provided no evidence that the stormwater discharge from the Kupe Production Station have caused any significant adverse effects on the macroinvertebrate communities of the Kapuni Stream.

Copies of biomonitoring reports for this site are available from the Council upon request.




Figure 6 Biomonitoring sites in the Kapuni Stream in relation to the Kupe Production Station, with taxa number, MCI scores and SQMCI scores for each site, summer 2023

#### 2.1.4 Summary of water abstractions reported by Beach Energy

Figure 7 provides a summary of the total daily abstraction volumes for the consented groundwater take from the Kupe bore field for operational purposes at the Kupe Production Station. On days where abstraction occurred the volumes were generally around 50 to 110 m<sup>3</sup>/day, well below the 3,500 m<sup>3</sup>/day allowed by condition 4 of consent 7010-1. A maximum take volume of 306 m<sup>3</sup>/day was recorded in May 2023. The maximum rate of take recorded was 12 L/s, well below the 40 L/s allowed by the consent. The total groundwater take for the year was 22,900 m<sup>3</sup>, this was a slight decrease compared with the previous year, however the overall increase is due to the water use associated with the inlet compressors wet surface air cooler which was installed in 2021. The majority of the abstraction occurred via the DT-1 bore at (over 99%).




Figure 7 Daily water abstraction volumes for Kupe Production Station under consent 7010-1

## 2.2 Air

### 2.2.1 Inspections

Air inspections were carried out in conjunction with site inspections as discussed in section 2.1.1 above. No issues regarding air quality were noted during the monitoring year.

### 2.2.2 Results of receiving environment monitoring

#### 2.2.2.1 Carbon monoxide and combustible gases

Exposure to low level carbon monoxide can cause nausea, dizziness, and disorientation. Higher levels of carbon monoxide can cause coma, collapse and loss of consciousness. The Resource Management (National Environmental Standards for Air Quality) Regulations 2004 (NES-AQ) for exposure to carbon monoxide is  $10 \text{ mg/m}^3$  averaged over an 8-hr period.

Since monitoring began in 2016 the concentration of carbon monoxide measured at the monitoring locations has never exceeded or approached the NES-AQ limit. In the previous year the results for the maximum carbon monoxide concentration was  $1.49 \text{ mg/m}^3$ , significantly lower than the NES-AQ limit of  $10 \text{ mg/m}^3$ .

Lower Explosive Limit (LEL) is the concentration of flammable gas, vapour, or mist in ambient air, below which an explosive gas atmosphere will not be formed. In past years methane has been used as a proxy for LEL and is measured using the MultiRae. Last year the instrument recorded methane at 0.1% of the LEL. This low result is to be expected given that methane will likely readily disperse over the distance between the source and the instrument.



Given that there have not been any significant changes to activities on-site or scale of production it is unlikely that the concentration of carbon monoxide and percentage LEL at the monitoring site during this monitoring year would be significantly different than last year.

#### 2.2.2.2 PM<sub>10</sub> particulates

Fine particulate less than 10 µm in diameter (PM<sub>10</sub>) can enter deep into the lungs significantly reducing the exchange of gases across the lung walls. Inhalation of PM<sub>10</sub> at high concentrations can cause cardiovascular conditions such as asthma and chronic pulmonary diseases.

PM<sub>10</sub> comes from multiple natural and anthropogenic sources including vehicle emissions, crustal matter and the combustion of fossil fuels. During the previous year's two-day monitoring the 24-hr average PM<sub>10</sub> concentrations was reported to be 13.4 µg/m<sup>3</sup> (day 1) and 12.9 µg/m<sup>3</sup> (day 2), significantly lower than the NES-AQ limit of 50 µg/m<sup>3</sup> (24-hr average)

The Kupe production station is located in a rural area and the level of background PM<sub>10</sub> is likely to be a result of vehicle emissions from Lower Inaha Rd to the east, dust from unsealed roads, and other rural activities such as fertiliser application. On this basis the background concentration of PM<sub>10</sub> in the area is likely to be low and therefore discharges from the combustion of natural gas at the Kupe site are not likely to cause ambient concentrations to approach the NES-AQ limit.

#### 2.2.2.3 Nitrogen oxides

From 2014 onwards, the Council implemented a coordinated region-wide compliance monitoring programme to measure nitrogen oxides (NOx). The programme involves deploying measuring devices at 24 NOx monitoring sites (including two sites in the vicinity of Kupe Production Station) on the same day, with retrieval three weeks later. This approach assists the Council in further evaluating the effects of local and regional emission sources and ambient air quality in the region.

The consent covering air discharges from the Kupe Production Station has specific limits related to particular gases. Special condition 18 of consent 6545-1 sets a limit on the nitrogen dioxide concentration at or beyond the production station's boundary. The limit is expressed as 200 µg/m<sup>3</sup> for a one hour average or 100 µg/m<sup>3</sup> for a 24 hour average exposure.

NOx passive adsorption discs were placed at two locations in the vicinity of the Kupe Production Station on one occasion during the year under review. The discs were left in place for a period of 21 days. The calculated one hour and 24 hour theoretical maximum NOx concentrations found at Kupe Production Station during the year under review equate to 4.9 µg/m<sup>3</sup> and 2.6 µg/m<sup>3</sup>, respectively. The results show that the ambient ground level concentration of NOx is well below the limits set out by consent 6545-1.

### 2.2.3 Summary of flaring volumes reported by Beach Energy

A summary of gas flaring and fuel use at Kupe Production Station under consents 6545-1 and 6546-1 is provided in Figure 8.

The total volume flared over the period (April 2022-March 2023) was 2,699,672 m<sup>3</sup>, a decrease compared with the previous 12 months (3,319,931m<sup>3</sup>). The Company attributes the decline in flaring over the previous five monitoring years to improvements in plant reliability and operational practice enhancements. The quantities flared each month vary and most flaring is related to process incidents, for example: compressor trips, compressor maintenance activities, weather events affecting power supply, and when gas flows are off-specification. No visible smoke events were recorded and no complaints regarding flaring or other air emissions at the production station were received by the Company or the Council during the 2022-2023 period.




Figure 8 Monthly gas flaring and fuel use for Kupe Production Station

### 2.3 Incidents, investigations, and interventions

The monitoring programme for the year was based on what was considered to be an appropriate level of monitoring, review of data, and liaison with the Company. During the year matters may arise which require additional activity by the Council, for example provision of advice and information, or investigation of potential or actual causes of non-compliance or failure to maintain good practices. A pro-active approach, that in the first instance avoids issues occurring, is favoured.

For all significant compliance issues, as well as complaints from the public, the Council maintains a database record. The record includes events where the individual/organisation concerned has itself notified the Council. Details of any investigation and corrective action taken are recorded for non-compliant events.

Complaints may be alleged to be associated with a particular site. If there is potentially an issue of legal liability, the Council must be able to prove by investigation that the identified individual/organisation is indeed the source of the incident (or that the allegation cannot be proven).

In the 2022-2023 period, the Council was not required to undertake significant additional investigations and interventions, or record incidents, in association with the Company's conditions in resource consents or provisions in Regional Plans.

## 3 Discussion

### 3.1 Discussion of site performance

Monitoring of the Kupe Production Station during the 2022-2023 year found that the site was well managed. All consent conditions relating to site operations and management were complied with.

### 3.2 Environmental effects of exercise of consents

Site inspections found that the stormwater systems were constructed and maintained in accordance with consent conditions and operating effectively.

Sampling and biomonitoring did not indicate that the stormwater discharges from the Kupe Production Station had caused adverse effects on the water quality of the Kapuni Stream.

There were no adverse effects on the environment resulting from the exercise of the air discharge consents. The ambient air quality monitoring at the site showed that levels of nitrogen oxides were below levels of concern at the time of sampling. No offensive or objectionable odours were detected beyond the boundary during inspections and there were no complaints in relation to air emissions from the site.

### 3.3 Evaluation of performance

A tabular summary of the consent holder's compliance record for the year under review is set out in Tables 6-14.

Table 6 Summary of performance for consent 6531-1

<b>Purpose: To disturb the seabed and foreshore of the coastal marine area by the process of erection, placement, use, alteration, extension, maintenance or removal of up to six pipelines and one power/fibre optic cable connecting an offshore wellhead/platform to the foreshore at mean high water spring</b>		
<b>Condition requirement</b>	<b>Means of monitoring during period under review</b>	<b>Compliance achieved?</b>
1. Exercise of consent in accordance with application	Inspection and liaison with consent holder	Yes
2. Pipe laying management plan to be provided	Provided February 2007	Yes
3. Programme of installation to be provided	Provided February 2007	Yes
4. Notification prior to maintenance work	Notification received	Yes
5. Contingency plan to be provided	Latest update received December 2021	Yes
6. Best practicable option to prevent or minimise adverse effects	Inspection and liaison with consent holder	Yes
7. Seabed disturbance to be minimised	Liaison with consent holder, work proposal submitted	Yes
8. Disturbance to be within a 100 m corridor	Liaison with consent holder, work proposal submitted	Yes

<b>Purpose: To disturb the seabed and foreshore of the coastal marine area by the process of erection, placement, use, alteration, extension, maintenance or removal of up to six pipelines and one power/fibre optic cable connecting an offshore wellhead/platform to the foreshore at mean high water spring</b>		
<b>Condition requirement</b>	<b>Means of monitoring during period under review</b>	<b>Compliance achieved?</b>
9. Disturbance to comply with noise standards	Liaison with consent holder, work proposal submitted	Yes
10. Work to cease on discovery of archaeological remains	No remains discovered	N/A
11. Consent holder to undertake pre and post lay monitoring surveys	Surveys complete	Yes
12. Lapse of consent	Consent exercised	N/A
13. Optional review provision re environmental effects	Next option for review in June 2029	N/A
Overall assessment of consent compliance and environmental performance in respect of this consent		<b>High</b>
Overall assessment of administrative performance in respect of this consent		<b>High</b>

N/A = not applicable

Table 7 Summary of performance for consent 6532-1

<b>Purpose: To erect, place, use, reconstruct, alter, extend and maintain within the coastal marine area up to six pipelines connecting an offshore wellhead/platform to the foreshore at mean high water spring, with structures situated under the seabed from approximately 1,200 m offshore to mean high water spring, and the related occupation of the seabed</b>		
<b>Condition requirement</b>	<b>Means of monitoring during period under review</b>	<b>Compliance achieved?</b>
1. Exercise of consent in accordance with application	Inspection and liaison with consent holder	Yes
2. Pipe laying management plan to be provided	Provided February 2007	Yes
3. Programme of installation to be provided	Provided February 2007	Yes
4. Notification prior to maintenance work	No maintenance during period under review	N/A
5. Contingency plan to be provided	Latest update received December 2021	Yes
6. Best practicable option to prevent or minimise adverse effects	No maintenance during period under review	N/A
7. Disturbance to comply with noise standards	No maintenance during period under review	N/A
8. Survey and map of position of pipeline to be provided	Provided by consent holder	Yes

<b>Purpose: To erect, place, use, reconstruct, alter, extend and maintain within the coastal marine area up to six pipelines connecting an offshore wellhead/platform to the foreshore at mean high water spring, with structures situated under the seabed from approximately 1,200 m offshore to mean high water spring, and the related occupation of the seabed</b>		
<b>Condition requirement</b>	<b>Means of monitoring during period under review</b>	<b>Compliance achieved?</b>
9. Consent holder to undertake pre and post lay monitoring surveys	Surveys complete	Yes
10. Structures to be removed and area reinstated if and when no longer required	Structures still in use	N/A
11. Lapse of consent	Consent exercised	N/A
12. Optional review provision re environmental effects	Next option for review June 2029	N/A
Overall assessment of consent compliance and environmental performance in respect of this consent		<b>High</b>
Overall assessment of administrative performance in respect of this consent		<b>High</b>

Table 8 Summary of performance for consent 6533-1

<b>Purpose: To occupy the coastal marine area for a distance of 250 m either side of the centre-line of a 100 metre wide pipeline corridor, from the outer limit of the territorial sea of New Zealand to mean high water spring, in a manner that will restrict public access</b>		
<b>Condition requirement</b>	<b>Means of monitoring during period under review</b>	<b>Compliance achieved?</b>
1. Exercise of consent in accordance with application	Inspection and liaison with consent holder	Yes
2. Public access to be maintained	Inspection and liaison with consent holder	Yes
3. Notification prior to works involving restriction of public access	No works requiring restriction carried out during period	N/A
4. Consent holder to survey and map position of the structure	Provided by consent holder	Yes
5. Lapse of consent	Consent exercised	N/A
6. Optional review provision re environmental effects	Next option for review June 2029	N/A
Overall assessment of consent compliance and environmental performance in respect of this consent		<b>High</b>
Overall assessment of administrative performance in respect of this consent		<b>High</b>

Table 9 Summary of performance for consent 6543-1

<b>Purpose: To discharge pipeline hydrotesting water and treated stormwater from the Kupe Production Station via a stormwater/firewater storage pond system, and to discharge stormwater from the Dangerous Goods Storage stormwater system into the Kapuni Stream</b>		
<b>Condition requirement</b>	<b>Means of monitoring during period under review</b>	<b>Compliance achieved?</b>
1. Exercise of consent in accordance with application	Inspection and liaison with consent holder	Yes
2. Plans of stormwater catchment and drainage pathways to be provided on completion of site	Plans received on completion	Yes
3. Notification prior to exercise of consent	Notifications received	Yes
4. Consent holder to review contingency plan for the site to include Dangerous Goods Store (DGS)	Review undertaken	Yes
5. Consent holder to adopt best practicable option	Inspection and liaison with consent holder	Yes
6. All discharges to be treated through stormwater treatment system (excluding DGS)	Inspection	Yes
7. All hazardous substance storage areas to be bunded	Inspection	Yes
8. Limits on contaminants in discharge	Sampling	Yes
9. Effects in receiving water	Inspections, sampling and biomonitoring	Yes
10. Lapse of consent	Consent exercised	N/A
11. Optional review provision re environmental effects	Next option for review June 2029	N/A
Overall assessment of consent compliance and environmental performance in respect of this consent		<b>High</b>
Overall assessment of administrative performance in respect of this consent		<b>High</b>

Table 10 Summary of performance for consent 6545-1

<b>Purpose: To discharge emissions to air from combustion involving the flaring of petroleum products incidental to the treatment of gas at the Kupe Production Station</b>		
<b>Condition requirement</b>	<b>Means of monitoring during period under review</b>	<b>Compliance achieved?</b>
1. Exercise of consent in accordance with application	Inspection and liaison with consent holder	Yes
2. Consent holder to adopt best practicable option	Inspection and liaison with consent holder	Yes

<b>Purpose: To discharge emissions to air from combustion involving the flaring of petroleum products incidental to the treatment of gas at the Kupe Production Station</b>		
<b>Condition requirement</b>	<b>Means of monitoring during period under review</b>	<b>Compliance achieved?</b>
3. Most appropriate process equipment to minimise emissions	Inspection and liaison with consent holder	Yes
4. Consent holder to provide analysis of typical gas stream on request	Not requested during period under review	N/A
5. Consent holder to supply Council with report in May each year	Report received	Yes
6. Consent holder to consult with Council prior to significantly altering equipment or processes	Inspection and liaison with consent holder	Yes
7. Consent holder to provide a final site layout prior to commencement of production	Plans received	Yes
8. Notification to neighbours prior to commissioning	Letter sent by Origin Energy in October 2009	Yes
9. Notification of incidents	No incidents reported	Yes
10. Consent holder to supply record of all smoke emitting incidents upon request	Flaring report received	Yes
11. Consent holder to maintain a log of all continuous flaring incidents	Flaring report received	Yes
12. All practicable steps undertaken to minimise flaring	Measures discussed in flaring report	Yes
13. Prevention of dense black smoke from being discharged from flare	Inspection and liaison with consent holder	Yes
14. Consent holder to notify Council of continuous flaring	Notifications received	Yes
15. Discharge not to give rise to odour, dust or smoke beyond the boundary	Inspection	Yes
16. Discharge not to give rise to hazardous, toxic or noxious contaminant beyond the boundary	Inspection	Yes
17. Limits on carbon monoxide in the discharge	Not assessed during period under review	N/A
18. Limits on nitrogen dioxide in discharge	Air monitoring	Yes

<b>Purpose: To discharge emissions to air from combustion involving the flaring of petroleum products incidental to the treatment of gas at the Kupe Production Station</b>		
<b>Condition requirement</b>	<b>Means of monitoring during period under review</b>	<b>Compliance achieved?</b>
19. Limits on other contaminants	Not assessed during period under review	N/A
20. Lapse of consent	Consent exercised	N/A
21. Optional review of consent	Next option for review June 2029	N/A
Overall assessment of consent compliance and environmental performance in respect of this consent		<b>High</b>
Overall assessment of administrative performance in respect of this consent		<b>High</b>

Table 11 Summary of performance for consent 6546-1

<b>Purpose: To discharge emissions to air as products of combustion from the Kupe Production Station involving equipment burning natural gas as fuel where the maximum heat release is in excess of 10 megawatts, together with miscellaneous emissions</b>		
<b>Condition requirement</b>	<b>Means of monitoring during period under review</b>	<b>Compliance achieved?</b>
1. Exercise of consent in accordance with application	Inspection and liaison with consent holder	Yes
2. Consent holder to adopt best practicable option	Inspection and liaison with consent holder	Yes
3. Most appropriate process equipment to minimise emissions	Inspection and liaison with consent holder	Yes
4. Consent holder to provide analysis of typical gas stream on request	Not requested during period under review	N/A
5. Consent holder to supply Council with report in May each year	Report received	Yes
6. Consent holder to consult with Council prior to significantly altering equipment or processes	Inspection and liaison with consent holder	Yes
7. Consent holder to provide a final site layout prior to commencement of production	Plans received	Yes
8. Notification of incidents	No incidents reported	Yes
9. Consent holder to supply record of all smoke emitting incidents upon request	Flaring report received	Yes
10. Discharge not to give rise to dangerous levels of contaminants at or beyond boundary	Not assessed during period under review	N/A



<b>Purpose: To discharge emissions to air as products of combustion from the Kupe Production Station involving equipment burning natural gas as fuel where the maximum heat release is in excess of 10 megawatts, together with miscellaneous emissions</b>		
<b>Condition requirement</b>	<b>Means of monitoring during period under review</b>	<b>Compliance achieved?</b>
11. Discharge not to give rise to odour, dust or smoke beyond the boundary	Inspection	Yes
12. Discharge not to give rise to hazardous, toxic or noxious contaminant beyond the boundary	Not assessed during period under review	N/A
13. Limits on carbon monoxide in the discharge	Not assessed during period under review	N/A
14. Limits on nitrogen dioxide in discharge	Air monitoring	Yes
15. Limits on other contaminants	Not assessed during period under review	N/A
16. Lapse of consent	Consent exercised	N/A
17. Optional review of consent	Next option for review June 2029	N/A
Overall assessment of consent compliance and environmental performance in respect of this consent		<b>High</b>
Overall assessment of administrative performance in respect of this consent		<b>High</b>

Table 12 Summary of performance for consent 6629-1

<b>Purpose: To erect, place, use, reconstruct, alter, extend and maintain within the coastal marine area one power/fibre optic cable connecting an offshore wellhead/platform to the foreshore at mean high water spring, with structures situated under the seabed from approximately 1,200 m offshore to mean high water spring, and the related occupation of the seabed</b>		
<b>Condition requirement</b>	<b>Means of monitoring during period under review</b>	<b>Compliance achieved?</b>
1. Exercise of consent in accordance with application	Inspection and liaison with consent holder	Yes
2. Pipe laying management plan to be provided	Provided in 2007	Yes
3. Programme of installation to be provided	Provided in 2007	Yes
4. Notification prior to maintenance work	No maintenance during period under review	Yes
5. Contingency plan to be provided	Latest update received December 2021	Yes
6. Best practicable option to prevent or minimise adverse effects	Inspection and liaison with consent holder	Yes
7. Works to comply with noise standards	Inspection and liaison with consent holder	Yes

<b>Purpose: To erect, place, use, reconstruct, alter, extend and maintain within the coastal marine area one power/fibre optic cable connecting an offshore wellhead/platform to the foreshore at mean high water spring, with structures situated under the seabed from approximately 1,200 m offshore to mean high water spring, and the related occupation of the seabed</b>		
<b>Condition requirement</b>	<b>Means of monitoring during period under review</b>	<b>Compliance achieved?</b>
8. Consent holder to survey and map position of structures	Plans received	Yes
9. Pre-lay and post-lay monitoring surveys of pipeline corridor	Surveys completed	Yes
10. Structures removed and area reinstated when no longer required	Structures still in use	N/A
11. Lapse of consent	Consent exercised	N/A
12. Review of consent	Next option for review June 2029	N/A
Overall assessment of consent compliance and environmental performance in respect of this consent		<b>High</b>
Overall assessment of administrative performance in respect of this consent		<b>High</b>

Table 13 Summary of performance for consent 6979-1

<b>Purpose: To install, construct and maintain up to seven water bores for horizontal directional drilling, pipeline hydro-testing, and production station operation purposes</b>		
<b>Condition requirement</b>	<b>Means of monitoring during period under review</b>	<b>Compliance achieved?</b>
1. Exercise of consent in accordance with application	Inspection and liaison with consent holder	Yes
2. Consent holder to supply bore completion log	Provided in 2007	Yes
3. Bores to be cased and sealed	Inspection and bore logs	Yes
4. Consent holder to mitigate any adverse environmental effects	Inspection and liaison with consent holder	Yes
5. Consent holder to decommission bores when no longer required	Bores still in use	N/A
6. Written notification of decommission	Bores still in use	N/A
7. Lapse of consent	Consent exercised	N/A
8. Review of consent	Next option for review June 2029	N/A
Overall assessment of consent compliance and environmental performance in respect of this consent		<b>High</b>
Overall assessment of administrative performance in respect of this consent		<b>High</b>

Table 14 Summary of performance for consent 7010-1

<b>Purpose: To take and use up to 3,500 m<sup>3</sup>/day groundwater at a maximum rate of 40 L/s as a combined total from up to seven water bores in a bore field for the purpose of horizontal directional drilling, pipeline hydro-testing, production station operation and operations at the Manutahi-D, Manutahi-C, and Kauri-F wellsites</b>		
<b>Condition requirement</b>	<b>Means of monitoring during period under review</b>	<b>Compliance achieved?</b>
1. Exercise of consent in accordance with application	Review of abstraction data	Yes
2. Notification prior to exercise of consent	Notification received in October 2006	Yes
3. Results of pump test to be provided	Provided in March 2007	Yes
4. Volume of abstraction not to exceed 3500 m <sup>3</sup> day and 40 L/s	Review of abstraction data	Yes
5. Abstraction not to cause more than 10% lowering of static water level	Not monitored during period under review	N/A
6. Abstraction not to cause the intrusion of saltwater	Review of abstraction data	Yes
7. Consent holder to maintain daily records of abstraction	Records supplied electronically, on a daily basis, as per Resource Management (Measurement and Reporting of Water Takes) Regulations 2020.	Yes
8. Consent holder to install groundwater monitoring piezometers	Piezometers installed into groundwater bores only extracting from an unconfined aquifer. Piezometers not required for the two bores installed into the confined aquifer.	Yes
9. Consent holder to install and maintain a water meter	Installed in 2007. Meter verified in September 2019, next verification due 2024	Yes
10. Consent subject to monitoring by Council	Records reviewed and meter inspected	Yes
11. Lapse of consent	Consent exercised	N/A
12. Review of consent	Next option for review June 2029	N/A
Overall assessment of consent compliance and environmental performance in respect of this consent		<b>High</b>
Overall assessment of administrative performance in respect of this consent		<b>High</b>

Table 15 Evaluation of environmental performance over time

Year	Consent no	High	Good	Improvement req	Poor
2010-11	6531-1, 6532-1, 6533-1, 6543-1, 6545-1, 6546-1, 6629-1, 6979-1, 7010-1	8	-	-	--
	6546-1	-	1	-	-
2011-12	6531-1, 6532-1, 6533-1, 6543-1, 6545-1, 6546-1, 6629-1, 6979-1, 7010-1	9	-	-	-
2012-13	6531-1, 6532-1, 6533-1, 6543-1, 6545-1, 6546-1, 6629-1, 6979-1, 7010-1	9	-	-	-
2013-14	6531-1, 6532-1, 6533-1, 6543-1, 6545-1, 6546-1, 6629-1, 6979-1, 7010-1	9	-	-	-
2014-15	6531-1, 6532-1, 6533-1, 6543-1, 6545-1, 6546-1, 6629-1, 6979-1, 7010-1	9	-	-	-
2015-16	6531-1, 6532-1, 6533-1, 6543-1, 6545-1, 6546-1, 6629-1, 6979-1, 7010-1	9	-	-	-
2016-17	6531-1, 6532-1, 6533-1, 6543-1, 6545-1, 6546-1, 6629-1, 6979-1, 7010-1	9	-	-	-
2017-18	6531-1, 6532-1, 6533-1, 6543-1, 6545-1, 6546-1, 6629-1, 6979-1, 7010-1	9	-	-	-
2018-19	6531-1, 6532-1, 6533-1, 6543-1, 6545-1, 6546-1, 6629-1, 6979-1, 7010-1	9	-	-	-
2019-2020	6531-1, 6532-1, 6533-1, 6543-1, 6545-1, 6546-1, 6629-1, 6979-1, 7010-1	9	-	-	-
2020-2021	6531-1, 6532-1, 6533-1, 6543-1, 6545-1, 6546-1, 6629-1, 6979-1, 7010-1	9	-	-	-
2021-2022	6531-1, 6532-1, 6533-1, 6543-1, 6545-1, 6546-1, 6629-1, 6979-1, 7010-1	9	-	-	-
Totals		107	1	0	0

During the year, the Company demonstrated a high level of both environmental performance and administrative compliance with the resource consents as defined in in Appendix II.

### 3.4 Recommendations from the 2021-2022 Annual Report

In the 2021-2022 Annual Report, it was recommended:

1. THAT in the first instance, monitoring of consented activities at the Kupe Production Station in the 2022-2023 year continue at the same level as in 2021-2022.
2. THAT should there be issues with environmental or administrative performance in 2022-2023, monitoring may be adjusted to reflect any additional investigation or intervention as found necessary.
3. THAT the option for reviews of resource consents 6531-1, 6532-1, 6533-1, 6543-1, 6545-1, 6546-1, 6629-1, 6979-1 and 7010-1 in June 2023, as set out in conditions of the consents, not be exercised, on the grounds that the current conditions are adequate.

Recommendations one and three were implemented, while additional monitoring was not considered necessary as per recommendation two.

### 3.5 Alterations to monitoring programmes for 2023-2024

In designing and implementing the monitoring programmes for air/water discharges in the region, the Council has taken into account:

- the extent of information already made available through monitoring or other means to date;
- its relevance under the RMA;
- the Council's obligations to monitor consented activities and their effects under the RMA;
- the record of administrative and environmental performances of the consent holder; and
- reporting to the regional community.

The Council also takes into account the scope of assessments required at the time of renewal of permits, and the need to maintain a sound understanding of industrial processes within Taranaki exercising resource consents.

No planned changes have been made to the 2023-2024 monitoring programme.

It should be noted that the proposed programme represents a reasonable and risk-based level of monitoring for the site in question. The Council reserves the right to subsequently adjust the programme from that initially prepared, should the need arise if potential or actual non-compliance is determined at any time during 2023-2024.

## 4 Recommendations

1. THAT in the first instance, monitoring of consented activities at the Kupe Production Station in the 2023-2024 year continue at the same level as in 2022-2023.
2. THAT should there be issues with environmental or administrative performance in 2023-2024, monitoring may be adjusted to reflect any additional investigation or intervention as found necessary.

## Glossary of common terms and abbreviations

The following abbreviations and terms may be used within this report:

Biomonitoring	Assessing the health of the environment using aquatic organisms.
Bund	A wall around a tank to contain its contents in the case of a leak.
Conductivity	Conductivity is an indication of the level of dissolved salts in a sample, usually measured at 25°C and expressed in mS/m.
Fresh	Elevated flow in a stream, such as after heavy rainfall.
g/m <sup>3</sup>	Grams per cubic metre, and equivalent to milligrams per litre (mg/L). In water, this is also equivalent to parts per million (ppm), but the same does not apply to gaseous mixtures.
IBC	Intermediate bulk container; reusable, multi-use industrial-grade containers engineered for the mass handling, transport and storage of liquids, semi-solids, pastes, or solids.
Incident	An event that is alleged or is found to have occurred that may have actual or potential environmental consequences or may involve non-compliance with a consent or rule in a regional plan. Registration of an incident by the Council does not automatically mean such an outcome had actually occurred.
Intervention	Action/s taken by Council to instruct or direct actions be taken to avoid or reduce the likelihood of an incident occurring.
Investigation	Action taken by Council to establish what were the circumstances/events surrounding an incident including any allegations of an incident.
Incident Register	The Incident Register contains a list of events recorded by the Council on the basis that they may have the potential or actual environmental consequences that may represent a breach of a consent or provision in a Regional Plan.
L/s	Litres per second.
m <sup>2</sup>	Square metres.
MCI	Macroinvertebrate community index: a numerical indication of the state of biological life in a stream that takes into account the sensitivity of the taxa present to organic pollution in stony habitats.
MfE	Ministry for the Environment.
Mixing zone	The zone below a discharge point where the discharge is not fully mixed with the receiving environment. For a stream, conventionally taken as a length equivalent to 7 times the width of the stream at the discharge point.
mS/m	Millisiemens per metre.
NTU	Nephelometric Turbidity Unit, a measure of the turbidity of water.
O&G	Oil and grease, defined as anything that will dissolve into a particular organic solvent (e.g. hexane). May include both animal material (fats) and mineral matter (hydrocarbons).
pH	A numerical system for measuring acidity in solutions, with 7 as neutral. Numbers lower than 7 are increasingly acidic and higher than 7 are increasingly alkaline. The scale is logarithmic i.e. a change of 1 represents a ten-fold change in strength. For example, a pH of 4 is ten times more acidic than a pH of 5.

Physicochemical	Measurement of both physical properties (e.g. temperature, clarity, density) and chemical determinants (e.g. metals and nutrients) to characterise the state of an environment.
PM <sub>10</sub>	Relatively fine airborne particles (less than 10 micrometre diameter, respectively).
Resource consent	Refer Section 87 of the RMA. Resource consents include land use consents (refer Sections 9 and 13 of the RMA), coastal permits (Sections 12, 14 and 15), water permits (Section 14) and discharge permits (Section 15).
RMA	<i>Resource Management Act 1991</i> and including all subsequent amendments.
Sm <sup>3</sup>	Standard cubic metre
SS	Suspended solids.
SQMCI	Semi quantitative macroinvertebrate community index.
Temp	Temperature, measured in °C (degrees Celsius).
Turb	Turbidity, expressed in NTU and FNU.
UI	Unauthorised Incident.

For further information on analytical methods, contact an Environmental Quality Manager.



## Bibliography and references

- Ministry for the Environment. 2018. *Best Practice Guidelines for Compliance, Monitoring and Enforcement under the Resource Management Act 1991*. Wellington: Ministry for the Environment.
- Taranaki Regional Council (2023): *Biomonitoring of the Kapuni Stream in relation to stormwater discharges from the Kupe Production Station, March 2023* (FK002).
- Taranaki Regional Council (2023): *Biomonitoring of the Kapuni Stream in relation to stormwater discharges from the Kupe Production Station, October 2022* (FK001).
- Taranaki Regional Council (2023): *Ambient Air Quality Monitoring at Kupe Production Station 2022-2023*. Internal memorandum.
- Taranaki Regional Council (2022): *Beach Energy Resources (Kupe) Ltd Kupe Production Station Monitoring Programme Annual Report 2021-2022*. Technical Report 2022-64
- Taranaki Regional Council (2021): *Beach Energy Resources (Kupe) Ltd Kupe Production Station Monitoring Programme Annual Report 2020-2021*. Technical Report 2021-34
- Taranaki Regional Council (2020): *Beach Energy Resources (Kupe) Ltd Kupe Production Station Monitoring Programme Annual Report 2019-2020*. Technical Report 2020-73
- Taranaki Regional Council (2019): *Beach Energy Resources (Kupe) Ltd Kupe Production Station Monitoring Programme Annual Report 2018-2019*. Technical Report 2019-43
- Taranaki Regional Council (2019): *Beach Energy Resources (Kupe) Ltd Kupe Production Station Monitoring Programme Annual Report 2017-2018*. Technical Report 2018-75.
- Taranaki Regional Council (2018): *Origin Energy Resources (Kupe) Ltd Kupe Production Station Monitoring Programme Annual Report 2016-2017*. Technical Report 2017-51.
- Taranaki Regional Council (2016): *Origin Energy Resources (Kupe) Ltd Kupe Production Station Monitoring Programme Annual Report 2015-2016*. Technical Report 2016-21.
- Taranaki Regional Council (2016): *Origin Energy Resources (Kupe) Ltd Kupe Production Station Monitoring Programme Annual Report 2014-2015*. Technical Report 2015-98.
- Taranaki Regional Council (2015): *Origin Energy Resources (Kupe) Ltd Kupe Production Station Monitoring Programme Annual Report 2013-2014*. Technical Report 2014-125.
- Taranaki Regional Council (2013): *Origin Energy Resources (Kupe) Ltd Kupe Production Station Monitoring Programme Annual Report 2012-2013*. Technical Report 2013-26.
- Taranaki Regional Council (2012): *Origin Energy Resources (Kupe) Ltd Kupe Production Station Monitoring Programme Annual Report 2011-2012*. Technical Report 2012-24.
- Taranaki Regional Council (2011): *Origin Energy Resources (Kupe) Ltd Kupe Production Station Monitoring Programme Annual Report 2010-2011*. Technical Report 2011-19.
- Taranaki Regional Council (2010): *Origin Energy Resources (Kupe) Ltd Kupe Production Station Monitoring Programme Annual Report 2009-2010*. Technical Report 2010-27.
- Taranaki Regional Council (2010): *Origin Energy Resources (Kupe) Ltd Kupe Gas Project Monitoring Programme Report (Development Phase) 2006-2009*. Technical Report 2009-09.



# Appendix I

## Resource consents held by Beach Energy Resources (Kupe) Ltd

(For a copy of the signed resource consent  
please contact the TRC Consents department)

### Water abstraction permits

Section 14 of the RMA stipulates that no person may take, use, dam or divert any water, unless the activity is expressly allowed for by a resource consent or a rule in a regional plan, or it falls within some particular categories set out in Section 14. Permits authorising the abstraction of water are issued by the Council under Section 87(d) of the RMA.

### Water discharge permits

Section 15(1)(a) of the RMA stipulates that no person may discharge any contaminant into water, unless the activity is expressly allowed for by a resource consent or a rule in a regional plan, or by national regulations. Permits authorising discharges to water are issued by the Council under Section 87(e) of the RMA.

### Air discharge permits

Section 15(1)(c) of the RMA stipulates that no person may discharge any contaminant from any industrial or trade premises into air, unless the activity is expressly allowed for by a resource consent, a rule in a regional plan, or by national regulations. Permits authorising discharges to air are issued by the Council under Section 87(e) of the RMA.

### Discharges of wastes to land

Sections 15(1)(b) and (d) of the RMA stipulate that no person may discharge any contaminant onto land if it may then enter water, or from any industrial or trade premises onto land under any circumstances, unless the activity is expressly allowed for by a resource consent, a rule in a regional plan, or by national regulations. Permits authorising the discharge of wastes to land are issued by the Council under Section 87(e) of the RMA.

### Land use permits

Section 13(1)(a) of the RMA stipulates that no person may in relation to the bed of any lake or river use, erect, reconstruct, place, alter, extend, remove, or demolish any structure or part of any structure in, on, under, or over the bed, unless the activity is expressly allowed for by a resource consent, a rule in a regional plan, or by national regulations. Land use permits are issued by the Council under Section 87(a) of the RMA.

### Coastal permits

Section 12(1)(b) of the RMA stipulates that no person may erect, reconstruct, place, alter, extend, remove, or demolish any structure that is fixed in, on, under, or over any foreshore or seabed, unless the activity is expressly allowed for by a resource consent, a rule in a regional plan, or by national regulations. Coastal permits are issued by the Council under Section 87(c) of the RMA.

**Coastal Permit**  
**Pursuant to the Resource Management Act 1991**  
**a resource consent is hereby granted by the**  
**Taranaki Regional Council**

Name of  
Consent Holder: Beach Energy Resources NZ (Kupe) Limited  
Private Bag 2022  
New Plymouth 4342

Decision Date  
(Change): 7 March 2012

Commencement Date  
(Change): 7 March 2012 (Granted Date: 9 December 2005)

**Conditions of Consent**

Consent Granted: To disturb the seabed and foreshore of the coastal marine area by the process of erection, placement, use, alteration, extension, maintenance or removal of up to six pipelines and one power/fibre optic cable connecting an offshore wellhead/platform to the foreshore at mean high water spring

Expiry Date: 1 June 2039

Review Date(s): June 2023, June 2029, June 2034

Site Location: Kupe Production Station, Kupe Project, offshore pipelines, from mean high water spring directly south of Inaha Road, Inaha, Manaia, to the coastal marine area boundary 22 km further south

Grid Reference (NZTM) 1699850E-5617662N

Catchment: Tasman Sea

*For General, Standard and Special conditions  
pertaining to this consent please see reverse side of this document*

### **General condition**

- a. The consent holder shall pay to the Taranaki Regional Council all the administration, monitoring and supervision costs of this consent, fixed in accordance with section 36 of the Resource Management Act 1991.

### **Special conditions**

1. The exercise of this consent shall be undertaken generally in accordance with the documentation submitted in support of applications 3501 and 6970, and special condition 2. In the case of any contradiction between the documentation submitted in support of applications 3501 and 6970, and the conditions of this consent, the conditions of this consent shall prevail.
2. At least one month prior to the exercise of this consent the consent holder shall provide, to the written satisfaction of the Chief Executive, Taranaki Regional Council, detailed plans of the activity to confirm that the proposal is generally in accordance with the application and supporting documentation and will comply with all of the conditions of this consent.
3. At least 10 working days prior to the commencement of works the consent holder shall provide the Taranaki Regional Council with a programme for the disturbance associated with installation/construction (or removal) of the pipeline(s) including: a schedule of proposed start dates and an estimation of the duration of the works, and details of the contractor including contact information for the project manager.
4. The consent holder shall notify the Chief Executive, Taranaki Regional Council, in writing at least 48 hours prior to commencement and upon completion of any subsequent maintenance works which would involve disturbance of, or deposition or discharge to, the coastal marine area.
5. Prior to the exercise of this consent the consent holder shall provide to the satisfaction of the Chief Executive, Taranaki Regional Council, a written contingency plan outlining measures to be undertaken in the event of a spill as a result of works authorised by this consent.
6. The consent holder shall at all times adopt the best practicable option, as defined in section 2 of the Resource Management Act 1991, to avoid or minimise the discharge of silt, sediments or any other contaminants into coastal water or onto the foreshore or seabed and to avoid or minimise the disturbance of the foreshore or seabed and any adverse effects on coastal water quality or ecosystems.
7. The consent holder shall ensure that the duration, area and volume of seabed disturbance shall, so far as is practicable, be minimised to the satisfaction of the Chief Executive, Taranaki Regional Council.
8. The consent holder shall ensure that all disturbance, including the placement of displaced boulders, shall be contained within a 100 metre wide disturbance corridor. Outside of the 100 metre wide disturbance corridor the exercise of this consent shall not give rise to any significant adverse ecological effects including effects to kaimoana.

## Consent 6531-1

9. The disturbance authorised by this consent shall comply with the noise standards as outlined within section 4.4.3 of the Regional Coastal Plan for Taranaki.
10. In the event that any archaeological remains are discovered as a result of works authorised by this consent, the works shall cease immediately at the affected site and tangata whenua and the Chief Executive, Taranaki Regional Council, shall be notified within one working day. Works may recommence at the affected area when advised to do so by the Chief Executive, Taranaki Regional Council. Such advice shall be given after the Chief Executive has considered: tangata whenua interest and values, the consent holder's interests, the interests of the public generally, and any archaeological or scientific evidence. The New Zealand Police, Coroner, and Historic Places Trust shall also be contacted as appropriate, and the work shall not recommence in the affected area until any necessary statutory authorisations or consent have been obtained.
11. The consent holder shall undertake pre-lay and post-lay monitoring surveys of the pipeline corridor, to the satisfaction of the Chief Executive, Taranaki Regional Council. The monitoring shall include one survey prior to disturbance, one survey immediately following laying of the pipelines, and one survey approximately 1 year following laying of the pipelines. The results of the monitoring shall be provided to the Chief Executive, Taranaki Regional Council, upon request.
12. This consent shall lapse on the expiry of five (5) years after the date of commencement of this consent, unless the consent is given effect to before the end of that period or the Taranaki Regional Council fixes a longer period pursuant to section 125(1)(b) of the Resource Management Act 1991.
13. In accordance with section 128 and section 129 of the Resource Management Act 1991, the Taranaki Regional Council may serve notice of its intention to review, amend, delete or add to the conditions of this resource consent by giving notice of review during the month of June 2011 and/or June 2017 and/or June 2023 and/or June 2029 and/or June 2034, for the purpose of ensuring that the conditions are adequate to deal with any adverse effects on the environment arising from the exercise of this resource consent, which were either not foreseen at the time the application was considered or which it was not appropriate to deal with at the time.

Transferred at Stratford on 17 April 2018

For and on behalf of  
Taranaki Regional Council

---

A D McLay  
**Director - Resource Management**





**Coastal Permit**  
**Pursuant to the Resource Management Act 1991**  
**a resource consent is hereby granted by the**  
**Taranaki Regional Council**

Name of Consent Holder: Beach Energy Resources NZ (Kupe) Limited  
Private Bag 2022  
New Plymouth 4342

Decision Date (Change): 7 March 2012

Commencement Date (Change): 7 March 2012 (Granted Date: 9 December 2005)

**Conditions of Consent**

Consent Granted: To erect, place, use, reconstruct, alter, extend and maintain within the coastal marine area up to six pipelines connecting an offshore wellhead/platform to the foreshore at mean high water spring, with structures situated under the seabed from approximately 1200 metres offshore to mean high water spring, and the related occupation of the seabed

Expiry Date: 1 June 2039

Review Date(s): June 2023, June 2029, June 2034

Site Location: Kupe Project, offshore pipelines, from mean high water spring directly south of Inaha Road, Inaha, Manaia, to the coastal marine area boundary 22 km further south

Grid Reference (NZTM) 1699850E-5617662N

Catchment: Tasman Sea

*For General, Standard and Special conditions  
pertaining to this consent please see reverse side of this document*

### **General condition**

- a. The consent holder shall pay to the Taranaki Regional Council all the administration, monitoring and supervision costs of this consent, fixed in accordance with section 36 of the Resource Management Act 1991.

### **Special conditions**

1. The exercise of this consent shall be undertaken generally in accordance with the documentation submitted in support of applications 3502 and 6971, and special condition 2. In the case of any contradiction between the documentation submitted in support of applications 3502 and 6971, and the conditions of this consent, the conditions of this consent shall prevail.
2. At least one month prior to the exercise of this consent the consent holder shall provide, to the written satisfaction of the Chief Executive, detailed plans of the activity to confirm that the proposal is generally in accordance with the application and supporting documentation and will comply with all of the conditions of this consent.
3. At least 10 working days prior to the commencement of works the consent holder shall provide the Taranaki Regional Council with a programme for the installation/construction of the pipeline(s), including: a schedule of proposed start dates and an estimation of the duration of the works, and details of the contractor including contact information for the project manager.
4. The consent holder shall notify the Chief Executive, Taranaki Regional Council, in writing at least 48 hours prior to commencement and upon completion of any subsequent maintenance works which would involve disturbance of, or deposition, or discharge to, the coastal marine area.
5. Prior to the exercise of this consent the consent holder shall provide, to the satisfaction of the Chief Executive, Taranaki Regional Council, a written construction contingency plan, outlining measures to be undertaken in the event of a spill as a result of works authorised by this consent. Further, prior to the exercise of this consent the consent holder shall provide to the Chief Executive, Taranaki Regional Council, written confirmation of the acceptance by the Maritime Safety Authority of a New Zealand Offshore Installation Site Marine Oil Spill Contingency Plan.
6. The consent holder shall at all times adopt the best practicable option, as defined in section 2 of the Resource Management Act 1991, to avoid or minimise the discharge of any contaminants into coastal water or onto the foreshore or seabed and to avoid or minimise any adverse effects on coastal water quality or ecosystems.
7. The construction, use, maintenance and removal of the structure(s) authorised by this consent shall comply with the noise standards as outlined within section 4.4.3 of the Regional Coastal Plan for Taranaki.

## Consent 6532-1

8. The consent holder shall survey and map the position of the pipeline(s), (including details of the pipeline(s) position in relation to the seabed), within 90 days of the completion of their construction, and shall provide a copy of the plan showing the precise location (to within plus or minus 5 metres) of the structure(s) on/in the seabed, to the Taranaki Regional Council, the Hydrographic Office, Royal New Zealand Navy, and the Maritime Safety Authority.
9. The consent holder shall undertake pre-lay and post-lay monitoring surveys of the pipeline corridor, to the satisfaction of the Chief Executive, Taranaki Regional Council. The monitoring shall include one survey prior to disturbance, one survey immediately following laying of the pipelines, and one survey approximately 1 year following laying of the pipelines. The results of the monitoring shall be provided to the Chief Executive, Taranaki Regional Council, upon request.
10. Except with the written agreement of the Chief Executive, Taranaki Regional Council, all structures authorised by this consent shall be removed and the area(s) reinstated, if and when the structure(s) are no longer required. The consent holder shall notify the Chief Executive, Taranaki Regional Council in writing at least 1 month prior to any structure(s) removal. Reinstatement shall be to the satisfaction of the Chief Executive, Taranaki Regional Council.
11. This consent shall lapse on the expiry of five (5) years after the date of commencement of this consent, unless the consent is given effect to before the end of that period or the Taranaki Regional Council fixes a longer period pursuant to section 125(1)(b) of the Resource Management Act 1991.
12. In accordance with section 128 and section 129 of the Resource Management Act 1991, the Taranaki Regional Council may serve notice of its intention to review, amend, delete or add to the conditions of this resource consent by giving notice of review during the month of June 2011 and/or June 2017 and/or June 2023 and/or June 2029 and/or June 2034, for the purpose of ensuring that the conditions are adequate to deal with any adverse effects on the environment arising from the exercise of this resource consent, which were either not foreseen at the time the application was considered or which it was not appropriate to deal with at the time.

Transferred at Stratford on 17 April 2018

For and on behalf of  
Taranaki Regional Council

---

A D McLay  
**Director - Resource Management**



**Coastal Permit  
Pursuant to the Resource Management Act 1991  
a resource consent is hereby granted by the  
Taranaki Regional Council**

Name of  
Consent Holder: Beach Energy Resources NZ (Kupe) Limited  
Private Bag 2022  
New Plymouth 4342

Decision Date: 9 December 2005

Commencement Date: 9 December 2005

**Conditions of Consent**

Consent Granted: To occupy the coastal marine area for a distance of 250 metres either side of the centre-line of a 100 metre wide pipeline corridor, from the outer limit of the territorial sea of New Zealand to mean high water spring, in a manner that will restrict public access

Expiry Date: 1 June 2039

Review Date(s): June 2023, June 2029, June 2034

Site Location: Kupe Project, offshore pipelines, from mean high water spring directly south of Inaha Road, Inaha, Manaia, to the coastal marine area boundary 22 km further south

Grid Reference (NZTM) 1699850E-5617660N

Catchment: Tasman Sea

*For General, Standard and Special conditions  
pertaining to this consent please see reverse side of this document*

### **General conditions**

- a) That on receipt of a requirement from the Chief Executive, Taranaki Regional Council (hereinafter the Chief Executive), the consent holder shall, within the time specified in the requirement, supply the information required relating to the exercise of this consent.
- b) That unless it is otherwise specified in the conditions of this consent, compliance with any monitoring requirement imposed by this consent must be at the consent holder's own expense.
- c) That the consent holder shall pay to the Council all required administrative charges fixed by the Council pursuant to section 36 in relation to:
  - i) the administration, monitoring and supervision of this consent; and
  - ii) charges authorised by regulations.

### **Special conditions**

1. The exercise of this consent shall be undertaken generally in accordance with the documentation submitted in support of application 3503. In the case of any contradiction between the documentation submitted in support of application 3503 and the conditions of this consent, the conditions of this consent shall prevail.
2. With the exception of the area required for safety purposes during: construction, inspection, maintenance or removal, of the structure(s) licensed by coastal permit 6532 and 6629; or the disturbance licensed by coastal permit 6531, the exercise of this consent shall not prevent the free passage of any member of the public through the coastal marine area (subject however to any restrictions imposed under the Submarine Cables and Pipelines Protection Act 1996 in relation to fishing operations).
3. The consent holder shall notify the Chief Executive, Taranaki Regional Council in writing at least 48 hours prior to commencement and upon completion of any subsequent maintenance works which would involve restriction of public access within the coastal marine area.
4. The consent holder shall survey and map the position of the structure(s) within 90 days of the completion of their construction, and shall provide a copy of the plan showing the precise location (to within plus or minus 5 metres) of the structure(s) on the seabed, and the location of the occupied areas to the Taranaki Regional Council, the Hydrographic Office, Royal New Zealand Navy, and the Maritime Safety Authority.
5. This consent shall lapse on the expiry of five (5) years after the date of commencement of this consent, unless the consent is given effect to before the end of that period or the Taranaki Regional Council fixes a longer period pursuant to section 125(1)(b) of the Resource Management Act 1991.

## Consent 6533-1

6. In accordance with section 128 and section 129 of the Resource Management Act 1991, the Taranaki Regional Council may serve notice of its intention to review, amend, delete or add to the conditions of this resource consent by giving notice of review during the month of June 2011 and/or June 2017 and/or June 2023 and/or June 2029 and/or June 2034, for the purpose of ensuring that the conditions are adequate to deal with any adverse effects on the environment arising from the exercise of this resource consent, which were either not foreseen at the time the application was considered or which it was not appropriate to deal with at the time.

Transferred at Stratford on 17 April 2018

For and on behalf of  
Taranaki Regional Council

---

A D McLay  
**Director - Resource Management**





**Discharge Permit**  
**Pursuant to the Resource Management Act 1991**  
**a resource consent is hereby granted by the**  
**Taranaki Regional Council**

Name of Consent Holder:	Beach Energy Resources NZ (Kupe) Limited	
Decision Date (Change):	3 September 2021	
Commencement Date (Change):	3 September 2021	(Granted Date: 8 December 2016)

**Conditions of Consent**

Consent Granted:	To discharge pipeline hydrotesting water, cooling water and treated stormwater from the Kupe Production Station via a stormwater/firewater storage pond system, and to discharge stormwater from the Dangerous Goods Storage stormwater system into the Kapuni Stream	
Expiry Date:	1 June 2039	
Review Date(s):	June 2023, June 2029, June 2034	
Site Location:	Kupe Production Station, 192 Lower Inaha Road, Inaha	
Grid Reference (NZTM)	1699150E-5618660N	
Catchment:	Kapuni	

*For General, Standard and Special conditions  
pertaining to this consent please see reverse side of this document*

### **General condition**

- a. The consent holder shall pay to the Taranaki Regional Council all the administration, monitoring and supervision costs of this consent, fixed in accordance with section 36 of the Resource Management Act 1991.

### **Special conditions**

1. The exercise of this consent shall be undertaken in general accordance with the information provided in support of the original application for this consent and with any subsequent application to change consent conditions and special condition 2. In the case of any contradiction between applications the later application shall prevail, and where there is conflict between an application and the conditions of this consent, the conditions of this consent shall prevail.
2. Within one month of the completion of the development of the site the consent holder shall provide, to the written satisfaction of the Chief Executive, Taranaki Regional Council, detailed plans of stormwater catchment and drainage pathways, including clean areas, potentially contaminated areas, and bunded areas, and the containment, treatment and discharge systems put into place.
3. The consent holder shall notify the Chief Executive, Taranaki Regional Council, in writing at least seven days prior to the exercise of this consent.
4. The consent holder shall review the contingency plan for the site and include, if necessary, the new Dangerous Goods Store. The consent holder shall provide the plan for the written approval of the Chief Executive, Taranaki Regional Council. The plan shall include site specific details relating to contingency planning for the site.
5. The consent holder shall at all times adopt the best practicable option, as defined in section 2 of the Resource Management Act 1991, to prevent or minimise any adverse effects of the discharge on any water body.
6. All stormwater, cooling and hydrotest water to be discharged under this permit shall be directed for treatment through the stormwater treatment system for discharge, excluding the stormwater discharge from the Dangerous Goods Storage stormwater system, which shall be discharged into the Kapuni Stream, in accordance with the special conditions of this consent.
7. The only contaminant allowed in the cooling water that is included in the discharge is the corrosion/scale inhibitor, 3D TRASAR 3DT465, or another similar product that has no greater potential to cause adverse effects in the receiving environment. The consent holder shall advise the Chief Executive, Taranaki Regional Council if the specific corrosion/scale inhibitor in the discharge changes.
8. Any above ground hazardous substances storage areas shall be bunded with drainage to sumps, or other appropriate recovery systems, and not directly to the stormwater catchment.

## Consent 6543-1.3

9. The following concentrations shall not be exceeded in the discharge:

<b>Component</b>	<b>Concentration</b>
pH (range)	6.0-9.0
suspended solids	100 gm <sup>-3</sup>
total recoverable hydrocarbons (infrared spectroscopic technique)	15 gm <sup>-3</sup>
chloride	230 gm <sup>-3</sup>

This condition shall apply prior to the entry of the treated stormwater into the Kapuni Stream at a designated sampling point(s) approved by the Chief Executive, Taranaki Regional Council.

10. After allowing for reasonable mixing, within a mixing zone extending 50 metres downstream of the discharge point, the discharge shall not give rise to any of the following effects in the receiving waters of the Kapuni Stream the production of any conspicuous oil or grease films, scums or foams, or floatable or suspended materials;
- the production of any conspicuous oil or grease films, scums or foams, or floatable or suspended materials;
  - any conspicuous change in the colour or visual clarity;
  - any emission of objectionable odour;
  - the rendering of fresh water unsuitable for consumption by farm animals;
  - any significant adverse effects on aquatic life.
11. In accordance with section 128 and section 129 of the Resource Management Act 1991, the Taranaki Regional Council may serve notice of its intention to review, amend, delete or add to the conditions of this resource consent by giving notice of review during the month of June 2023 and/or June 2029 and/or June 2034, for the purpose of ensuring that the conditions are adequate to deal with any adverse effects on the environment arising from the exercise of this resource consent, which were either not foreseen at the time the application was considered or which it was not appropriate to deal with at the time.

Signed at Stratford on 3 September 2021

For and on behalf of  
Taranaki Regional Council



---

A D McLay

**Director - Resource Management**



**Discharge Permit**  
**Pursuant to the Resource Management Act 1991**  
**a resource consent is hereby granted by the**  
**Taranaki Regional Council**

Name of  
Consent Holder: Beach Energy Resources NZ (Kupe) Limited  
Private Bag 2022  
New Plymouth 4342

Decision Date  
(Change): 2 April 2007

Commencement Date  
(Change): 2 April 2007 (Granted Date: 21 June 2005)

**Conditions of Consent**

Consent Granted: To discharge emissions to air from combustion involving the flaring of petroleum products incidental to the treatment of gas at the Kupe Production Station

Expiry Date: 1 June 2039

Review Date(s): June 2023, June 2029, June 2034

Site Location: Kupe Project, west of Inaha Road, east of Kapuni Road (being a paper road) and south of Siggs Road (being a paper road), Inaha, Manaia (Production Station)

Grid Reference (NZTM) 1699750E-5618461N

*For General, Standard and Special conditions  
pertaining to this consent please see reverse side of this document*

### **General conditions**

- a) On receipt of a requirement from the Chief Executive, Taranaki Regional Council the consent holder shall, within the time specified in the requirement, supply the information required relating to the exercise of this consent.
- b) Unless it is otherwise specified in the conditions of this consent, compliance with any monitoring requirement imposed by this consent must be at the consent holder's own expense.
- c) The consent holder shall pay to the Council all required administrative charges fixed by the Council pursuant to section 36 in relation to:
  - i) the administration, monitoring and supervision of this consent; and
  - ii) charges authorised by regulations.

### **Special conditions**

#### **Condition 1 – changed**

1. The exercise of this consent shall be undertaken in general accordance with the documentation submitted in support of applications 3515 and 4498. In the case of any contradiction between the documentation submitted in support of application 3515 and 4498 and the conditions of this consent, the conditions of this consent shall prevail.

#### **Conditions 2 to 5 – unchanged**

2. The consent holder shall at all times adopt the best practicable option, as defined in section 2 of the Resource Management Act 1991, to prevent or minimise any actual or likely adverse effects on the environment associated with the discharge of contaminants into the environment arising from the emissions to air from the flare.
3. The consent holder shall minimise the emissions and impacts of air contaminants discharged from the flare by the selection of the most appropriate process equipment, process control equipment, emission control equipment, methods of control, supervision and operation, and the proper and effective operation, supervision, control and maintenance of all equipment and processes.
4. The consent holder shall make available to the Chief Executive upon request an analysis of a typical gas and/or condensate stream from the Kupe field, covering sulphur compound content and the content of compounds containing six or more carbon atoms in their molecular structure.

## Consent 6545-1

5. The consent holder shall provide to the Taranaki Regional Council during May of each year, for the duration of this consent, a report:
  - a) detailing gas combustion at the production station flares, including but not restricted to routine operational flaring and flaring logged as per condition 11;
  - b) detailing any measures that have been undertaken by the consent holder to improve the energy efficiency of the production station;
  - c) detailing any measures to reduce smoke emissions;
  - d) detailing any measures to reduce flaring,
  - e) addressing any other issue relevant to the minimisation or mitigation of emissions from the production station flare; and
  - f) detailing any complaints received and any measures undertaken to address complaints.

### **Condition 6 – changed**

6. Prior to undertaking any alterations to the plant equipment, processes or operations, which may substantially alter the nature or quantity of flare emissions other than as notified in consent applications 3515 and 4498, the consent holder shall first consult with the Chief Executive, Taranaki Regional Council, and shall obtain any necessary approvals under the Resource Management Act 1991.

### **Conditions 7 to 21 – unchanged**

7. Prior to the commencement of production, the consent holder shall supply to the Chief Executive, Taranaki Regional Council, a final site lay-out plan, demonstrating configuration of the facilities and equipment so as to avoid or mitigate the potential effects of air emissions.
8. At least 3 days before the commissioning of the plant, the consent holder shall undertake all practicable measures to notify owners or occupiers of properties within 1 kilometre of the boundary of the property on which the production station flare is located, of the possibility of flaring and smoke emissions. The consent holder shall include in the notification a 24-hour contact telephone number for a representative of the consent holder.
9. Any incident having an environmental effect or potential effect which has caused or is liable to cause substantiated complaint or a hazardous situation beyond the boundary of the property on which the production station flare is located, shall be notified to the Taranaki Regional Council, as soon as possible, followed by a written report to the Chief Executive, Taranaki Regional Council, within one week of the incident, with comment about the measures taken to minimise the impact of the incident and to prevent re-occurrence.
10. The consent holder shall keep and make available to the Chief Executive, Taranaki Regional Council, upon request, a record of all smoke emitting incidents, noting time, duration and cause. The consent holder shall also keep, and make available to the Chief Executive, upon request, a record of all complaints received as a result of the exercise of this consent.

## Consent 6545-1

11. The consent holder shall keep and maintain a log of all continuous flaring incidents longer than 5 minutes and any intermittent flaring lasting for an aggregate of 10 minutes or longer in any 60-minute period. Such a log shall contain the date, the start and finish times, the quantity and type of material flared, and the reason for flaring. This log shall be made available to the Chief Executive, Taranaki Regional Council, upon request, and summarised annually in the report required under condition 5. Flaring, under normal operation in the low pressure flare, of rich mono-ethylene glycol degasser vapour, condensate tank vapours, non-condensibles from tri-ethylene glycol/mono-ethylene glycol regeneration and purge gas shall be excluded from this requirement.
12. All practicable steps shall be taken to minimise flaring.
13. Other than in emergencies, the rate of depressurisation of the plant, or sections of the plant, shall be managed to prevent dense black smoke from being discharged from the flare.
14. The consent holder shall, whenever practicable, notify the Chief Executive, Taranaki Regional Council, whenever the continuous flaring of hydrocarbons (other than the flaring of rich mono-ethylene glycol degasser vapour, condensate tank vapours, non-condensibles from tri-ethylene glycol/mono-ethylene glycol regeneration and purge gas) is expected to occur for more than five minutes in duration.
15. The discharges authorised by this consent shall not, whether alone or in conjunction with any other emissions from the site arising through the exercise of any other consent, give rise to any levels of odour or dust or smoke that are offensive or obnoxious or objectionable at or beyond the site boundary in the opinion of an enforcement officer of the Taranaki Regional Council.
16. The consent holder shall not discharge any contaminant to air from the site at a rate or a quantity such that the contaminant, whether alone or in combination with other contaminants, is or is liable to be hazardous or toxic or noxious at or beyond the boundary of the property where the production station is located, or at any dwellinghouse.
17. The consent holder shall control all discharges of carbon monoxide to the atmosphere from the flare, whether alone or in conjunction with any other emissions from the site arising through the exercise of any other consent, in order that the maximum ground level concentration of carbon monoxide arising from the exercise of this consent measured under ambient conditions does not exceed 10 milligrams per cubic metre (eight-hour average exposure), or 30 milligrams per cubic metre (one-hour average exposure) at or beyond the boundary of the property on which the production station flare is located.
18. The consent holder shall control all discharges of nitrogen dioxide or its precursors to the atmosphere from the flare, whether alone or in conjunction with any other discharges to the atmosphere from the site arising through the exercise of any other consent, in order that the maximum ground level concentration of nitrogen dioxide arising from the exercise of this consent measured under ambient conditions does not exceed 200 micrograms per cubic metre (one hour average exposure), or 100 micrograms per cubic metre (twenty-four hour average exposure), at or beyond the boundary of the property on which the production station flare is located.



## Consent 6545-1

19. The consent holder shall control discharges to the atmosphere from the flare of contaminants other than carbon dioxide, carbon monoxide, and nitrogen oxides, whether alone or in conjunction with any other emissions from the site arising through the exercise of any other consent, in order that the maximum ground level concentration for any particular contaminant arising from the exercise of this consent, measured at or beyond the boundary of the property on which the production station flare is located, is not increased above background levels:
- a) by more than 1/30th of the relevant Workplace Exposure Standard-Time Weighted Average (exposure averaged over a duration as specified for the Workplace Exposure Standard-Time Weighted Average), or by more than 1/10th of the Workplace Exposure Standard-Short Term Exposure Limit over any short period of time (all terms as defined in Workplace Exposure Standards, 2002, Department of Labour); or
  - b) if no Short Term Exposure Limit is set, by more than the General Excursion Limit at any time (all terms as defined in Workplace Exposure Standards, 2002, Department of Labour).
20. This consent shall lapse on the expiry of five (5) years after the date of commencement of this consent, unless the consent is given effect to before the end of that period or the Taranaki Regional Council fixes a longer period pursuant to section 125(1)(b) of the Resource Management Act 1991.
21. In accordance with section 128 and section 129 of the Resource Management Act 1991, the Taranaki Regional Council may serve notice of its intention to review, amend, delete or add to the conditions of this resource consent within six months of receiving a report prepared by the consent holder pursuant to condition 5 of this consent, or by giving notice of review during the month of June 2007 and/or June 2009 and/or June 2011 and/or June 2017 and/or June 2023 and/or June 2029 and/or June 2034, for the purposes of:
- a) dealing with any significant adverse effect on the environment arising from the exercise of the consent which was not foreseen at the time the application was considered or which it was not appropriate to deal with at the time; and/or
  - b) requiring the consent holder to adopt the best practicable option to remove or reduce any adverse effect on the environment caused by the discharge; and/or
  - c) to alter, add or delete limits on mass discharge quantities or discharge or ambient concentrations of any contaminant or contaminants; and/or
  - d) taking into account any Act of Parliament, regulation, national policy statement or national environmental standard which relates to limiting, recording, or mitigating emissions of carbon dioxide and/or nitrogen dioxide, and which is relevant to the air discharge from the Kupe Production Station.

Transferred at Stratford on 17 April 2018

For and on behalf of  
Taranaki Regional Council

---

A D McLay  
**Director - Resource Management**



**Discharge Permit**  
**Pursuant to the Resource Management Act 1991**  
**a resource consent is hereby granted by the**  
**Taranaki Regional Council**

Name of Consent Holder: Beach Energy Resources NZ (Kupe) Limited  
Private Bag 2022  
New Plymouth 4342

Decision Date: 21 June 2005

Commencement Date: 21 June 2005

**Conditions of Consent**

Consent Granted: To discharge emissions to air as products of combustion from the Kupe Production Station involving equipment burning natural gas as fuel where the maximum heat release is in excess of 10 megawatts, together with miscellaneous emissions

Expiry Date: 1 June 2039

Review Date(s): June 2023, June 2029, June 2034

Site Location: Kupe Production Station, west of Inaha Road, east of Kapuni Road (being a paper road) and south of Siggs Road (being a paper road), Inaha, Manaia

Grid Reference (NZTM) 1699750E-5618461N

*For General, Standard and Special conditions  
pertaining to this consent please see reverse side of this document*

### General conditions

- a) On receipt of a requirement from the Chief Executive, Taranaki Regional Council the consent holder shall, within the time specified in the requirement, supply the information required relating to the exercise of this consent.
- b) Unless it is otherwise specified in the conditions of this consent, compliance with any monitoring requirement imposed by this consent must be at the consent holder's own expense.
- c) The consent holder shall pay to the Council all required administrative charges fixed by the Council pursuant to section 36 in relation to:
  - i) the administration, monitoring and supervision of this consent; and
  - ii) charges authorised by regulations.

### Special conditions

1. The exercise of this consent shall be undertaken generally in accordance with the documentation submitted in support of application 3516. In the case of any contradiction between the documentation submitted in support of application 3516 and the conditions of this consent, the conditions of this consent shall prevail.
2. The consent holder shall at all times adopt the best practicable option, as defined in Section 2 of the Resource Management Act 1991, to prevent or minimise any actual or likely adverse effects on the environment associated with the discharge of contaminants into the environment arising from the emissions to air from the site.
3. The consent holder shall minimise the emissions and impacts of air contaminants discharged from the site by the selection of the most appropriate process equipment, process control equipment, emission control equipment, methods of control, supervision and operation, and the proper and effective operation, supervision, control and maintenance of all equipment and processes.
4. The consent holder shall make available to the Chief Executive, Taranaki Regional Council, upon request an analysis of a typical gas and/or condensate stream from the Kupe field, covering sulphur compound content and the content of compounds containing six or more carbon atoms in their molecular structure.
5. The consent holder shall provide to the Taranaki Regional Council during May of each year, for the duration of this consent, a report:
  - a) detailing gas combustion at the production station;
  - b) detailing any measures that have been undertaken by the consent holder to improve the energy efficiency of the production station;
  - c) detailing any measures to reduce smoke emissions;
  - d) detailing any measures to reduce flaring;
  - e) addressing any other issue relevant to the minimisation or mitigation of emissions from the production station; and
  - f) detailing any complaints received and any measures undertaken to address complaints.

## Consent 6546-1

6. Prior to undertaking any alterations to the plant, processes or operations, which may significantly change the nature or quantity of contaminants emitted to air from the site, the consent holder shall first consult with the Chief Executive, Taranaki Regional Council, and shall obtain any necessary approvals under the Resource Management Act 1991.
7. Prior to the commencement of production, the consent holder shall supply to the Chief Executive, Taranaki Regional Council, a final site lay-out plan, demonstrating configuration of the facilities and equipment so as to avoid or mitigate the potential effects of air emissions.
8. Any incident having an environmental impact or potential environmental impact which has caused or is liable to cause substantiated complaint or a hazardous situation beyond the boundary of the property on which the production station is located, shall be notified to the Taranaki Regional Council, as soon as possible, followed by a written report to the Chief Executive, Taranaki Regional Council, within one week of the incident, with comment about the measures taken to minimise the impact of the incident and to prevent re-occurrence.
9. The consent holder shall keep and make available to the Chief Executive, Taranaki Regional Council, upon request, a record of all smoke emitting incidents and all relief valve releases, noting time, duration and cause. The consent holder shall also keep, and make available to the Chief Executive, upon request, a record of all complaints received as a result of the exercise of this consent.
10. The discharges authorised by this consent shall not, whether alone or in conjunction with any other emissions from the site arising through the exercise of any other consent, give rise to any dangerous levels of airborne contaminants at or beyond the boundary of the property including but not limited to any risk of fire or explosion.
11. The discharges authorised by this consent shall not, whether alone or in conjunction with any other emissions from the site arising through the exercise of any other consent, give rise to any levels of odour or dust or smoke that are offensive or obnoxious or objectionable at or beyond the boundary of the property on which the production station is located in the opinion of an enforcement officer of the Taranaki Regional Council.
12. The consent holder shall not discharge any contaminant to air from the site at a rate or a quantity such that the contaminant, whether alone or in conjunction with any other emissions from the site arising through the exercise of any other consent, is or is liable to be hazardous or toxic or noxious at or beyond the boundary of the property where the production station is located, or at any dwellinghouse.

13. The consent holder shall control all discharges of carbon monoxide to the atmosphere from the site, whether alone or in conjunction with any other emissions from the site arising through the exercise of any other consent, in order that the maximum ground level concentration of carbon monoxide arising from the exercise of this consent measured under ambient conditions does not exceed 10 milligrams per cubic metre (eight-hour average exposure), or 30 milligrams per cubic metre (one-hour average exposure) at or beyond the boundary of the property on which the production station is located.
14. The consent holder shall control all discharges of nitrogen dioxide or its precursors to the atmosphere from the site, whether alone or in conjunction with any other discharges to the atmosphere from the site arising through the exercise of any other consent, in order that the maximum ground level concentration of nitrogen dioxide arising from the exercise of this consent measured under ambient conditions does not exceed 200 micrograms per cubic metre (one hour average exposure), or 100 micrograms per cubic metre (twenty-four hour average exposure), at or beyond the boundary of the property on which the production station is located.
15. The consent holder shall control discharges to the atmosphere from the site of contaminants other than carbon dioxide, carbon monoxide, and nitrogen oxides, whether alone or in conjunction with any other emissions from the site arising through the exercise of any other consent, in order that the maximum ground level concentration for any particular contaminant arising from the exercise of this consent, measured at or beyond the boundary of the property on which the production station is located, is not increased above background levels:
  - a) by more than 1/30th of the relevant Workplace Exposure Standard-Time Weighted Average (exposure averaged over a duration as specified for the Workplace Exposure Standard-Time Weighted Average), or by more than 1/10th of the Workplace Exposure Standard-Short Term Exposure Limit over any short period of time (all terms as defined in Workplace Exposure Standards, 2002, Department of Labour); or
  - b) if no Short Term Exposure Limit is set, by more than the General Excursion Limit at any time (all terms as defined in Workplace Exposure Standards, 2002, Department of Labour).
16. This consent shall lapse on the expiry of five (5) years after the date of commencement of this consent, unless the consent is given effect to before the end of that period or the Taranaki Regional Council fixes a longer period pursuant to section 125(1)(b) of the Resource Management Act 1991.

## Consent 6546-1

17. In accordance with section 128 and section 129 of the Resource Management Act 1991, the Taranaki Regional Council may serve notice of its intention to review, amend, delete or add to the conditions of this resource consent within six months of receiving a report prepared by the consent holder pursuant to condition 5 of this consent, or by giving notice of review during the month of June 2007 and/or June 2009 and/or June 2011 and/or June 2017 and/or June 2023 and/or June 2029 and/or June 2034, for the purposes of:
- a) dealing with any significant adverse effect on the environment arising from the exercise of the consent which was not foreseen at the time the application was considered or which it was not appropriate to deal with at the time; and/or
  - b) requiring the consent holder to adopt the best practicable option to remove or reduce any adverse effect on the environment caused by the discharge; and/or
  - c) to alter, add or delete limits on mass discharge quantities or discharge or ambient concentrations of any contaminant or contaminants; and/or
  - d) taking into account any Act of Parliament, regulation, national policy statement or national environmental standard which relates to limiting, recording, or mitigating emissions of carbon dioxide and/or nitrogen dioxide, and which is relevant to the air discharge from the Kupe Production Station.

Transferred at Stratford on 17 April 2018

For and on behalf of  
Taranaki Regional Council

---

A D McLay  
**Director - Resource Management**





**Coastal Permit  
Pursuant to the Resource Management Act 1991  
a resource consent is hereby granted by the  
Taranaki Regional Council**

Name of Consent Holder: Beach Energy Resources NZ (Kupe) Limited  
Private Bag 2022  
New Plymouth 4342

Decision Date: 28 October 2005

Commencement Date: 28 October 2005

**Conditions of Consent**

Consent Granted: To erect, place, use, reconstruct, alter, extend and maintain within the coastal marine area one power/fibre optic cable connecting an offshore wellhead/platform to the foreshore at mean high water spring, with structures situated under the seabed from approximately 1200 metres offshore to mean high water spring, and the related occupation of the seabed

Expiry Date: 1 June 2039

Review Date(s): June 2023, June 2029, June 2034

Site Location: Kupe Project, offshore pipelines, from mean high water spring directly south of Inaha Road, Inaha, Manaia, to the coastal marine area boundary 22 km further south

Grid Reference (NZTM) 1699850E-5617660N

Catchment: Tasman Sea

*For General, Standard and Special conditions  
pertaining to this consent please see reverse side of this document*

### General conditions

- a) That on receipt of a requirement from the Chief Executive, Taranaki Regional Council (hereinafter the Chief Executive), the consent holder shall, within the time specified in the requirement, supply the information required relating to the exercise of this consent.
- b) That unless it is otherwise specified in the conditions of this consent, compliance with any monitoring requirement imposed by this consent must be at the consent holder's own expense.
- c) That the consent holder shall pay to the Council all required administrative charges fixed by the Council pursuant to section 36 in relation to:
  - i) the administration, monitoring and supervision of this consent; and
  - ii) charges authorised by regulations.

### Special conditions

1. The exercise of this consent shall be undertaken generally in accordance with the documentation submitted in support of application 3502, and special condition 2. In the case of any contradiction between the documentation submitted in support of application 3502 and the conditions of this consent, the conditions of this consent shall prevail.
2. At least one month prior to the exercise of this consent the consent holder shall provide, to the written satisfaction of the Chief Executive, Taranaki Regional Council, a detailed pipe laying management plan. The purpose of the management plan is to set out the investigations to be undertaken and the procedure to be adopted to minimise the disturbance to the seabed as a result of laying the pipelines. The management plan shall include, as a minimum:
  - a) a description of the results of the investigations undertaken by remotely operated vehicle to determine the optimum pipeline route;
  - b) a description of the method to be used to remove boulders from the pipeline route;
  - c) the timeframe over which the boulder clearing will be undertaken;
  - d) confirmation that the proposed activity is generally in accordance with the application and supporting documentation, and will comply with all the conditions of this consent; and
  - e) an outline of the measures to be used to ensure that consent conditions will be met.

The management plan shall be prepared in consultation with interested submitters to the application. However, the consent holder shall not be in breach of this condition if any party chooses not to comment on the draft management plan. Nor is the consent holder under any obligation to incorporate any particular suggestions or proposals advanced by any party.

## Consent 6629-1

3. At least 10 working days prior to the commencement of works the consent holder shall provide the Taranaki Regional Council with a programme for the installation/construction of the structure[s], including: a schedule of proposed start dates and an estimation of the duration of the works, and details of the contractor including contact information for the project manager.
4. The consent holder shall notify the Chief Executive, Taranaki Regional Council, in writing at least 48 hours prior to commencement and upon completion of any subsequent maintenance works which would involve disturbance of, or deposition, or discharge to, the coastal marine area.
5. Prior to the exercise of this consent the consent holder shall provide, to the satisfaction of the Chief Executive, Taranaki Regional Council, a written construction contingency plan, outlining measures to be undertaken in the event of a spill as a result of works authorised by this consent. Further, prior to the exercise of this consent the consent holder shall provide to the Chief Executive, Taranaki Regional Council, written confirmation of the acceptance by the Maritime Safety Authority of a New Zealand Offshore Installation Site Marine Oil Spill Contingency Plan.
6. The consent holder shall at all times adopt the best practicable option, as defined in section 2 of the Resource Management Act 1991, to avoid or minimise the discharge of any contaminants into coastal water or onto the foreshore or seabed and to avoid or minimise any adverse effects on coastal water quality or ecosystems.
7. The construction, use, maintenance and removal of the structure[s] authorised by this consent shall comply with the noise standards as outlined within section 4.4.3 of the Regional Coastal Plan for Taranaki.
8. The consent holder shall survey and map the position of the structure[s], [including details of the structure[s] position in relation to the seabed], within 90 days of the completion of their construction, and shall provide a copy of the plan showing the precise location [to within plus or minus 5 metres] of the structure[s] on/in the seabed, to the Taranaki Regional Council, the Hydrographic Office, Royal New Zealand Navy, and the Maritime Safety Authority.
9. The consent holder shall undertake pre-lay and post-lay monitoring surveys of the pipeline corridor, to the satisfaction of the Chief Executive, Taranaki Regional Council. The monitoring shall include one survey prior to disturbance, one survey immediately following laying of the pipelines, and one survey approximately 1 year following laying of the pipelines. The results of the monitoring shall be provided to the Chief Executive, Taranaki Regional Council, upon request.
10. Except with the written agreement of the Chief Executive, Taranaki Regional Council, all structures authorised by this consent shall be removed and the area[s] reinstated, if and when the structure[s] are no longer required. The consent holder shall notify the Chief Executive, Taranaki Regional Council in writing at least 1 month prior to any structure[s] removal. Reinstatement shall be to the satisfaction of the Chief Executive, Taranaki Regional Council.

## Consent 6629-1

11. This consent shall lapse on the expiry of five [5] years after the date of commencement of this consent, unless the consent is given effect to before the end of that period or the Taranaki Regional Council fixes a longer period pursuant to section 125(1)(b) of the Resource Management Act 1991.
12. In accordance with section 128 and section 129 of the Resource Management Act 1991, the Taranaki Regional Council may serve notice of its intention to review, amend, delete or add to the conditions of this resource consent by giving notice of review during the month of June 2011 and/or June 2017 and/or June 2023 and/or June 2029 and/or June 2034, for the purpose of ensuring that the conditions are adequate to deal with any adverse effects on the environment arising from the exercise of this resource consent, which were either not foreseen at the time the application was considered or which it was not appropriate to deal with at the time.

Transferred at Stratford on 17 April 2018

For and on behalf of  
Taranaki Regional Council

---

A D McLay  
**Director - Resource Management**

**Land Use Consent**  
**Pursuant to the Resource Management Act 1991**  
**a resource consent is hereby granted by the**  
**Taranaki Regional Council**

Name of Consent Holder: Beach Energy Resources NZ (Kupe) Limited  
Private Bag 2022  
New Plymouth 4342

Decision Date: 1 November 2006

Commencement Date: 1 November 2006

**Conditions of Consent**

Consent Granted: To install, construct and maintain up to seven water bores for horizontal directional drilling, pipeline hydro-testing, and production station operation purposes

Expiry Date: 1 June 2039

Review Date(s): June 2023, June 2029, June 2034

Site Location: Lower Inaha Road, Inaha

Grid Reference (NZTM) 1699850E-5618461N

Catchment: Inaha

*For General, Standard and Special conditions  
pertaining to this consent please see reverse side of this document*

### **General conditions**

- a) On receipt of a requirement from the Chief Executive, Taranaki Regional Council the consent holder shall, within the time specified in the requirement, supply the information required relating to the exercise of this consent.
- b) Unless it is otherwise specified in the conditions of this consent, compliance with any monitoring requirement imposed by this consent must be at the consent holder's own expense.
- c) The consent holder shall pay to the Council all required administrative charges fixed by the Council pursuant to section 36 in relation to:
  - i) the administration, monitoring and supervision of this consent; and
  - ii) charges authorised by regulations.

### **Special conditions**

1. The exercise of this consent shall be undertaken in general accordance with the documentation submitted in support of application 4392. In the case of any contradiction between the documentation submitted in support of application 4392 and the conditions of this consent, the conditions of this consent shall prevail.
2. The consent holder shall, within 28 days of the completion of each bore, provide a bore completion log to the satisfaction of the Chief Executive, Taranaki Regional Council.
3. The bores shall be cased and sealed to prevent the potential for aquifer cross-contamination and/or leakage from the surface.
4. The consent holder shall take all reasonable steps to mitigate any adverse environmental effects that may be caused by structural failure in any of the bores.
5. The consent holder shall properly decommission any bore no longer required.
6. The consent holder shall provide written notification to the Chief Executive, Taranaki Regional Council following the decommissioning of any bore, within 28 days of completion.
7. This consent shall lapse on the expiry of five years after the date of commencement of this consent, unless the consent is given effect to before the end of that period or the Taranaki Regional Council fixes a longer period pursuant to section 125(1)(b) of the Resource Management Act 1991.

Consent 6979-1

9. In accordance with section 128 and section 129 of the Resource Management Act 1991, the Taranaki Regional Council may serve notice of its intention to review, amend, delete or add to the conditions of this resource consent by giving notice of review during the month of June 2011 and/or June 2017 and/or 2023 and/or 2029 and/or 2034 for the purpose of ensuring that the conditions are adequate to deal with any adverse effects on the environment arising from the exercise of this resource consent, which were either not foreseen at the time the application was considered or which it was not appropriate to deal with at the time.

Transferred at Stratford on 17 April 2018

For and on behalf of  
Taranaki Regional Council

---

A D McLay  
**Director - Resource Management**





**Water Permit**  
**Pursuant to the Resource Management Act 1991**  
**a resource consent is hereby granted by the**  
**Taranaki Regional Council**

Name of Consent Holder:	Beach Energy Resources NZ (Kupe) Limited Private Bag 2022 New Plymouth 4342	
Decision Date (Change):	13 October 2011	
Commencement Date (Change):	13 October 2011	(Granted Date: 2 November 2006)

**Conditions of Consent**

Consent Granted:	To take and use up to 3,500 m <sup>3</sup> /day groundwater at a maximum rate of 40 l/s as a combined total from up to seven water bores in a bore field for the purpose of horizontal directional drilling, pipeline hydro-testing, production station operation and operations at the Manutahi-D, Manutahi-C, and Kauri-F wellsites	
Expiry Date:	1 June 2039	
Review Date(s):	June 2023, June 2029, June 2034	
Site Location:	Lower Inaha Road, Inaha (Kupe Production Station/Manutahi-D/Manutahi-C/Kauri-F)	
Grid Reference (NZTM)	1699935E-5618466N	
Catchment:	Inaha	

*For General, Standard and Special conditions  
pertaining to this consent please see reverse side of this document*

### **General conditions**

- a) On receipt of a requirement from the Chief Executive, Taranaki Regional Council the consent holder shall, within the time specified in the requirement, supply the information required relating to the exercise of this consent.
- b) Unless it is otherwise specified in the conditions of this consent, compliance with any monitoring requirement imposed by this consent must be at the consent holder's own expense.
- c) The consent holder shall pay to the Council all required administrative charges fixed by the Council pursuant to section 36 in relation to:
  - i) the administration, monitoring and supervision of this consent; and
  - ii) charges authorised by regulations.

### **Special conditions**

1. The exercise of this consent shall be undertaken in general accordance with the documentation submitted in support of applications 4430, 4585 and 6908 and shall ensure the efficient and effective use of water. In the case of any contradiction between the documentation submitted in support of applications 4430, 4585, and 6908 and the conditions of this consent, the conditions of this consent shall prevail.
2. The consent holder shall notify the Chief Executive, Taranaki Regional Council, in writing at least seven days prior to the exercise of this consent.
3. Prior to the exercise of this consent, the consent holder shall provide a report to Chief Executive, Taranaki Regional Council, detailing the results of pump testing (24-hour constant discharge at 40 l/s and recovery tests) of the bores used for water supply to show (1) that the abstraction is sustainable, and (2) the effects of the abstraction on flows in the Inaha Stream and the Kapuni Stream.
4. The volume of groundwater abstracted shall not exceed 3,500 cubic metres per day at a rate not exceeding 40 litres per second as a combined total from the bores in the bore field.
5. The abstraction shall not cause more than a 10% lowering of the static water level by interference in any adjacent registered bore located beyond the boundary of the bore field.
6. The abstraction shall not cause the intrusion of saltwater into any freshwater aquifer.
7. The consent holder shall maintain daily records of the abstraction from each bore including date, abstraction rate and daily volume, and pumping hours, and make these records available to the Chief Executive, Taranaki Regional Council, no later than 31 July of each year, or upon request.

## Consent 7010-1

8. Prior to the exercise of this consent for any groundwater bore extracting water from an unconfined aquifer, the consent holder shall install groundwater monitoring piezometers between the Kapuni Stream and Inaha Stream and the bore for the purposes of monitoring groundwater levels.
9. The consent holder shall install and maintain a water meter approved by the Chief Executive, Taranaki Regional Council, on each bore for the purposes of accurately recording the abstraction of water.
10. This consent shall be subject to monitoring by the Taranaki Regional Council and the consent holder shall meet all reasonable costs associated with the monitoring.
11. This consent shall lapse on the expiry of five years after the date of commencement of this consent, unless the consent is given effect to before the end of that period or the Taranaki Regional Council fixes a longer period pursuant to section 125(1)(b) of the Resource Management Act 1991.
12. In accordance with section 128 and section 129 of the Resource Management Act 1991, the Taranaki Regional Council may serve notice of its intention to review, amend, delete or add to the conditions of this resource consent by giving notice of review during the month of June 2011 and/or June 2017 and/or 2023 and/or 2029 and/or 2034, for the purpose of ensuring that the conditions are adequate to deal with any adverse effects on the environment arising from the exercise of this resource consent, which were either not foreseen at the time the application was considered or which it was not appropriate to deal with at the time.

Transferred at Stratford on 17 April 2018

For and on behalf of  
Taranaki Regional Council

---

A D McLay  
**Director - Resource Management**



## Appendix II

Categories used to evaluate environmental and administrative performance

## Categories used to evaluate environmental and administrative performance

Environmental performance is concerned with actual or likely effects on the receiving environment from the activities during the monitoring year. Administrative performance is concerned with the Company's approach to demonstrating consent compliance in site operations and management including the timely provision of information to Council (such as contingency plans and water take data) in accordance with consent conditions.

Events that were beyond the control of the consent holder and unforeseeable (that is a defence under the provisions of the RMA can be established) may be excluded with regard to the performance rating applied. For example loss of data due to a flood destroying deployed field equipment.

The categories used by the Council for this monitoring period, and their interpretation, are as follows:

### Environmental Performance

**High:** No or inconsequential (short-term duration, less than minor in severity) breaches of consent or regional plan parameters resulting from the activity; no adverse effects of significance noted or likely in the receiving environment. The Council did not record any verified unauthorised incidents involving environmental impacts and was not obliged to issue any abatement notices or infringement notices in relation to such impacts.

**Good:** Likely or actual adverse effects of activities on the receiving environment were negligible or minor at most. There were some such issues noted during monitoring, from self-reports, or during investigations of incidents reported to the Council by a third party but these items were not critical, and follow-up inspections showed they have been dealt with. These minor issues were resolved positively, co-operatively, and quickly. The Council was not obliged to issue any abatement notices or infringement notices in relation to the minor non-compliant effects; however abatement notices may have been issued to mitigate an identified potential for an environmental effect to occur.

For example:

- High suspended solid values recorded in discharge samples, however the discharge was to land or to receiving waters that were in high flow at the time;
- Strong odour beyond boundary but no residential properties or other recipient nearby.

**Improvement required:** Likely or actual adverse effects of activities on the receiving environment were more than minor, but not substantial. There were some issues noted during monitoring, from self-reports, or during investigations of incidents reported to the Council by a third party. Cumulative adverse effects of a persistent minor non-compliant activity could elevate a minor issue to this level. Abatement notices and infringement notices may have been issued in respect of effects.

**Poor:** Likely or actual adverse effects of activities on the receiving environment were significant. There were some items noted during monitoring, from self-reports, or during investigations of incidents reported to the Council by a third party. Cumulative adverse effects of a persistent moderate non-compliant activity could elevate an 'improvement required' issue to this level. Typically there were grounds for either a prosecution or an infringement notice in respect of effects.

### Administrative performance

**High:** The administrative requirements of the resource consents were met, or any failure to do this had trivial consequences and were addressed promptly and co-operatively.

**Good:** Perhaps some administrative requirements of the resource consents were not met at a particular time, however this was addressed without repeated interventions from the Council staff. Alternatively

adequate reason was provided for matters such as the no or late provision of information, interpretation of 'best practical option' for avoiding potential effects, etc.

**Improvement required:** Repeated interventions to meet the administrative requirements of the resource consents were made by Council staff. These matters took some time to resolve, or remained unresolved at the end of the period under review. The Council may have issued an abatement notice to attain compliance.

**Poor:** Material failings to meet the administrative requirements of the resource consents. Significant intervention by the Council was required. Typically there were grounds for an infringement notice.